

ANALYTICAL REPORT

Job Number: 420-110105-1

SDG Number: Pine Bush CSD - EJR

Job Description: Orange-Ulster BOCES

For:

Orange-Ulster BOCES

53 Gibson Road

Goshen, NY 10924

Attention: Jack DeGraw



Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

09/27/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

Job Narrative
420-J110105-1

Comments

Results are compared to NYSDOH drinking water standards other federal regulations may apply.

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

Metals

No analytical or quality issues were noted.

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-110105-1
SDG Number: Pine Bush CSD - EJR

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-110105-1
SDG Number: Pine Bush CSD - EJR

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Cusack, Renee	RC
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-110105-1
SDG Number: Pine Bush CSD - EJ R

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110105-1	1 - Girls Bathroom by Boiler Room Sink 1	Drinking Water	09/10/2016 0905	09/13/2016 1144
420-110105-2	2 - Girls Bathroom by Boiler Room Sink 2	Drinking Water	09/10/2016 0905	09/13/2016 1144
420-110105-3	3 - Custodial Slop Sink by Cafeteria	Drinking Water	09/10/2016 0907	09/13/2016 1144
420-110105-4	4 - Room 132 Bathroom Sink	Drinking Water	09/10/2016 0910	09/13/2016 1144
420-110105-5	5 - Kitchen Left Sink	Drinking Water	09/10/2016 0915	09/13/2016 1144
420-110105-6	6 - Kitchen Right Sink	Drinking Water	09/10/2016 0915	09/13/2016 1144
420-110105-7	7 - Kitchen Hand Sink	Drinking Water	09/10/2016 0917	09/13/2016 1144
420-110105-8	8 - Kitchen Bathroom Sink	Drinking Water	09/10/2016 0919	09/13/2016 1144
420-110105-9	9 - Fountain by Cafeteria	Drinking Water	09/10/2016 0920	09/13/2016 1144
420-110105-10	10 - Room 36 Sink	Drinking Water	09/10/2016 0921	09/13/2016 1144
420-110105-11	11 - Room 18 Sink	Drinking Water	09/10/2016 0922	09/13/2016 1144
420-110105-12	12 - Room 18 Fountain	Drinking Water	09/10/2016 0922	09/13/2016 1144
420-110105-13	13 - Room 20 Sink	Drinking Water	09/10/2016 0925	09/13/2016 1144
420-110105-14	14 - Room 20 Fountain	Drinking Water	09/10/2016 0925	09/13/2016 1144
420-110105-15	15 - Room 22 Sink	Drinking Water	09/10/2016 0927	09/13/2016 1144
420-110105-16	16 - Room 22 Fountain	Drinking Water	09/10/2016 0927	09/13/2016 1144
420-110105-17	17 - Room 24 Sink	Drinking Water	09/10/2016 0928	09/13/2016 1144
420-110105-18	18 - Room 24 Fountain	Drinking Water	09/10/2016 0928	09/13/2016 1144
420-110105-19	19 - Room 23 Sink	Drinking Water	09/10/2016 0930	09/13/2016 1144
420-110105-20	20 - Room 23 Fountain	Drinking Water	09/10/2016 0930	09/13/2016 1144
420-110105-21	21 - Girls Bathroom by Rm 23 Sink 1	Drinking Water	09/10/2016 0933	09/13/2016 1144
420-110105-22	22 - Girls Bathroom by Rm 23 Sink 2	Drinking Water	09/10/2016 0933	09/13/2016 1144
420-110105-23	23 - Slop Sink by Room 23	Drinking Water	09/10/2016 0935	09/13/2016 1144
420-110105-24	24 - Room 25 Sink	Drinking Water	09/10/2016 0937	09/13/2016 1144
420-110105-25	25 - Room 25 Fountain	Drinking Water	09/10/2016 0937	09/13/2016 1144
420-110105-26	26 - Room 27 Sink	Drinking Water	09/10/2016 0938	09/13/2016 1144
420-110105-27	27 - Room 27 Fountain	Drinking Water	09/10/2016 0938	09/13/2016 1144
420-110105-28	28 - Boys Bathroom by Room 25 Sink 1	Drinking Water	09/10/2016 0941	09/13/2016 1144
420-110105-29	29 - Boys Bathroom by Room 25 Sink 2	Drinking Water	09/10/2016 0941	09/13/2016 1144
420-110105-30	30 - Room 29 Sink	Drinking Water	09/10/2016 0943	09/13/2016 1144
420-110105-31	31 - Room 29 Fountain	Drinking Water	09/10/2016 0943	09/13/2016 1144
420-110105-32	32 - Room 26 Sink	Drinking Water	09/10/2016 0947	09/13/2016 1144
420-110105-33	33 - Room 26 Fountain	Drinking Water	09/10/2016 0947	09/13/2016 1144
420-110105-34	34 - Room 30 Sink	Drinking Water	09/10/2016 0949	09/13/2016 1144
420-110105-35	35 - Room 30 Fountain	Drinking Water	09/10/2016 0949	09/13/2016 1144
420-110105-36	36 - Room 31 Sink	Drinking Water	09/10/2016 0950	09/13/2016 1144
420-110105-37	37 - Room 31 Fountain	Drinking Water	09/10/2016 0950	09/13/2016 1144
420-110105-38	38 - Room 33 Sink	Drinking Water	09/10/2016 0955	09/13/2016 1144
420-110105-39	39 - Room 33 Fountain	Drinking Water	09/10/2016 0955	09/13/2016 1144
420-110105-40	40 - Room 35 Sink	Drinking Water	09/10/2016 0957	09/13/2016 1144

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-110105-1
SDG Number: Pine Bush CSD - EJRB

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110105-41	41 - Room 35 Fountain	Drinking Water	09/10/2016 0957	09/13/2016 1144
420-110105-42	42 - Room 37 Sink	Drinking Water	09/10/2016 0959	09/13/2016 1144
420-110105-43	43 - Room 37 Fountain	Drinking Water	09/10/2016 0059	09/13/2016 1144
420-110105-44	44 - Room 32 Sink	Drinking Water	09/10/2016 1001	09/13/2016 1144
420-110105-45	45 - Room 32 Fountain	Drinking Water	09/10/2016 1001	09/13/2016 1144
420-110105-46	46 - Room 39 Sink	Drinking Water	09/10/2016 1002	09/13/2016 1144
420-110105-47	47 - Room 39 Fountain	Drinking Water	09/10/2016 1002	09/13/2016 1144
420-110105-48	48 - Room 34 Sink	Drinking Water	09/10/2016 1003	09/13/2016 1144
420-110105-49	49 - Room 34 Fountain	Drinking Water	09/10/2016 1003	09/13/2016 1144
420-110105-50	50 - Left Fountain by Room 34	Drinking Water	09/10/2016 1005	09/13/2016 1144
420-110105-51	51 - Right Fountain by Room 34	Drinking Water	09/10/2016 1005	09/13/2016 1144
420-110105-52	52 - Room 46 Sink	Drinking Water	09/10/2016 1008	09/13/2016 1144
420-110105-53	53 - Room 46 Fountain	Drinking Water	09/10/2016 1008	09/13/2016 1144
420-110105-54	54 - Room 47 Sink	Drinking Water	09/10/2016 1011	09/13/2016 1144
420-110105-55	55 - Room 47 Fountain	Drinking Water	09/10/2016 1011	09/13/2016 1144
420-110105-56	56 - Room 48 Sink	Drinking Water	09/10/2016 1013	09/13/2016 1144
420-110105-57	57 - Room 48 Fountain	Drinking Water	09/10/2016 1013	09/13/2016 1144
420-110105-58	58 - Room 49 Sink	Drinking Water	09/10/2016 1016	09/13/2016 1144
420-110105-59	59 - Room 49 Fountain	Drinking Water	09/10/2016 1016	09/13/2016 1144
420-110105-60	60 - Room 50 Sink	Drinking Water	09/10/2016 1017	09/13/2016 1144
420-110105-61	61 - Room 50 Fountain	Drinking Water	09/10/2016 1017	09/13/2016 1144
420-110105-62	62 - Room 51 Sink	Drinking Water	09/10/2016 1019	09/13/2016 1144
420-110105-63	63 - Room 51 Fountain	Drinking Water	09/10/2016 1019	09/13/2016 1144
420-110105-64	64 - Room 52 Sink	Drinking Water	09/10/2016 1022	09/13/2016 1144
420-110105-65	65 - Room 52 Fountain	Drinking Water	09/10/2016 1022	09/13/2016 1144
420-110105-66	66 - Room 53 Sink	Drinking Water	09/10/2016 1024	09/13/2016 1144
420-110105-67	67 - Room 53 Sink	Drinking Water	09/10/2016 1024	09/13/2016 1144
420-110105-68	68 - Girls Bathroom by Rm 52 Sink 1	Drinking Water	09/10/2016 1025	09/13/2016 1144
420-110105-69	69 - Girls Bathroom by Rm 52 Sink 2	Drinking Water	09/10/2016 1025	09/13/2016 1144
420-110105-70	70 - Boys Bathroom by Rm 52 Sink 1	Drinking Water	09/10/2016 1027	09/13/2016 1144
420-110105-71	71 - Boys Bathroom by Rm 52 Sink 2	Drinking Water	09/10/2016 1027	09/13/2016 1144
420-110105-72	72 - Boys Bathroom by Rm 52 Sink 3	Drinking Water	09/10/2016 1027	09/13/2016 1144
420-110105-73	73 - Left Fountain by 61B	Drinking Water	09/10/2016 1030	09/13/2016 1144
420-110105-74	74 - Right Fountain by 61B	Drinking Water	09/10/2016 1030	09/13/2016 1144
420-110105-75	75 - Room 61 Sink	Drinking Water	09/10/2016 1032	09/13/2016 1144
420-110105-76	76 - Room 60 Sink	Drinking Water	09/10/2016 1033	09/13/2016 1144
420-110105-77	77 - Room 60 Bathroom Sink	Drinking Water	09/10/2016 1034	09/13/2016 1144
420-110105-78	78 - Boys Bathroom by Greeter Desk Sink 1	Drinking Water	09/10/2016 1043	09/13/2016 1144
420-110105-79	79 - Boys Bathroom by Greeter Desk Sink 2	Drinking Water	09/10/2016 1043	09/13/2016 1144

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-110105-1
SDG Number: Pine Bush CSD - EJR

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110105-80	80 - Office Left Bathroom Sink	Drinking Water	09/10/2016 1047	09/13/2016 1144
420-110105-81	81 - Office Right Bathroom Sink	Drinking Water	09/10/2016 1047	09/13/2016 1144
420-110105-82	82 - Nurse's Sink	Drinking Water	09/10/2016 1052	09/13/2016 1144
420-110105-83	83 - Nurse's Bathroom Sink	Drinking Water	09/10/2016 1052	09/13/2016 1144
420-110105-84	84 - Room 03 Sink	Drinking Water	09/10/2016 1054	09/13/2016 1144
420-110105-85	85 - Room 03 Fountain	Drinking Water	09/10/2016 1054	09/13/2016 1144
420-110105-86	86 - Room 02 Sink	Drinking Water	09/10/2016 1055	09/13/2016 1144
420-110105-87	87 - Room 02 Fountain	Drinking Water	09/10/2016 1055	09/13/2016 1144
420-110105-88	88 - Girls Bathroom by Rm 02 Sink 1	Drinking Water	09/10/2016 1058	09/13/2016 1144
420-110105-89	89 - Girls Bathroom by Rm 02 Sink 2	Drinking Water	09/10/2016 1058	09/13/2016 1144
420-110105-90	90 - Girls Bathroom by Rm 02 Sink 3	Drinking Water	09/10/2016 1058	09/13/2016 1144
420-110105-91	91 - Girls Bathroom by Rm 02 Sink 4	Drinking Water	09/10/2016 1058	09/13/2016 1144
420-110105-92	92 - Custodial Slop Sink by Rm 04	Drinking Water	09/10/2016 1100	09/13/2016 1144
420-110105-93	93 - Fountain by Room 04	Drinking Water	09/10/2016 1102	09/13/2016 1144
420-110105-94	94 - Boys Bathroom by 5A Sink 1	Drinking Water	09/10/2016 1105	09/13/2016 1144
420-110105-95	95 - Boys Bathroom by 5A Sink 2	Drinking Water	09/10/2016 1105	09/13/2016 1144
420-110105-96	96 - Boys Bathroom by 5A Sink 3	Drinking Water	09/10/2016 1105	09/13/2016 1144
420-110105-97	97 - Boys Bathroom by 5A Sink 4	Drinking Water	09/10/2016 1105	09/13/2016 1144
420-110105-98	98 - Room 04 Sink	Drinking Water	09/10/2016 1107	09/13/2016 1144
420-110105-99	99 - Room 04 Fountain	Drinking Water	09/10/2016 1107	09/13/2016 1144
420-110105-100	100 - Room 06 Sink	Drinking Water	09/10/2016 1110	09/13/2016 1144
420-110105-101	101 - Room 06 Fountain	Drinking Water	09/10/2016 1110	09/13/2016 1144
420-110105-102	102 - Room 07 Sink	Drinking Water	09/10/2016 1112	09/13/2016 1144
420-110105-103	103 - Room 07 Fountain	Drinking Water	09/10/2016 1112	09/13/2016 1144
420-110105-104	104 - Room 08 Sink	Drinking Water	09/10/2016 1113	09/13/2016 1144
420-110105-105	105 - Room 08 Fountain	Drinking Water	09/10/2016 1113	09/13/2016 1144
420-110105-106	106 - Room 09 Sink	Drinking Water	09/10/2016 1115	09/13/2016 1144
420-110105-107	107 - Room 09 Fountain	Drinking Water	09/10/2016 1115	09/13/2016 1144
420-110105-108	108 - Room 10 Sink	Drinking Water	09/10/2016 1118	09/13/2016 1144
420-110105-109	109 - Room 10 Fountain	Drinking Water	09/10/2016 1119	09/13/2016 1144
420-110105-110	110 - Room 11 Sink	Drinking Water	09/10/2016 1120	09/13/2016 1144
420-110105-111	111 - Room 12 Sink	Drinking Water	09/10/2016 1122	09/13/2016 1144
420-110105-112	112 - Room 12 Fountain	Drinking Water	09/10/2016 1122	09/13/2016 1144

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 1 - Girls Bathroom by Boiler Room Sink 1
Lab Sample ID: 420-110105-1

Date Sampled: 09/10/2016 0905
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 1929	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	3.65	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 2 - Girls Bathroom by Boiler Room Sink 2
Lab Sample ID: 420-110105-2

Date Sampled: 09/10/2016 0905
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 1933	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	5.75	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 3 - Custodial Slop Sink by Cafeteria
Lab Sample ID: 420-110105-3

Date Sampled: 09/10/2016 0907
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 1936	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	18.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 4 - Room 132 Bathroom Sink
Lab Sample ID: 420-110105-4

Date Sampled: 09/10/2016 0910
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/21/2016 1213	
Prep Method: 200			Date Prepared:	09/19/2016 1100	
Pb	54.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 5 - Kitchen Left Sink
Lab Sample ID: 420-110105-5

Date Sampled: 09/10/2016 0915
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 1940	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	2.83	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 6 - Kitchen Right Sink
Lab Sample ID: 420-110105-6

Date Sampled: 09/10/2016 0915
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 1943	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	9.22	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 7 - Kitchen Hand Sink
Lab Sample ID: 420-110105-7

Date Sampled: 09/10/2016 0917
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	1954	
			Date Prepared:	09/16/2016	1250	
	443	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 8 - Kitchen Bathroom Sink
Lab Sample ID: 420-110105-8

Date Sampled: 09/10/2016 0919
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed: 09/16/2016 1958			
Prep Method: 200		Date Prepared: 09/16/2016 1250			
Pb	4.07	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 9 - Fountain by Cafeteria
Lab Sample ID: 420-110105-9

Date Sampled: 09/10/2016 0920
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2001	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	2.02	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 10 - Room 36 Sink
Lab Sample ID: 420-110105-10

Date Sampled: 09/10/2016 0921
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2005	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	13.7	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 11 - Room 18 Sink
Lab Sample ID: 420-110105-11

Date Sampled: 09/10/2016 0922
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2008	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	15.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 12 - Room 18 Fountain
Lab Sample ID: 420-110105-12

Date Sampled: 09/10/2016 0922
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/21/2016 1218	
Prep Method: 200			Date Prepared:	09/19/2016 1100	
Pb	18.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 13 - Room 20 Sink
Lab Sample ID: 420-110105-13

Date Sampled: 09/10/2016 0925
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2012	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	14.6	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 14 - Room 20 Fountain
Lab Sample ID: 420-110105-14

Date Sampled: 09/10/2016 0925
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2015	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	1.61	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 15 - Room 22 Sink
Lab Sample ID: 420-110105-15

Date Sampled: 09/10/2016 0927
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2019	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	47.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 16 - Room 22 Fountain
Lab Sample ID: 420-110105-16

Date Sampled: 09/10/2016 0927
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2022	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	1.30	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 17 - Room 24 Sink
Lab Sample ID: 420-110105-17

Date Sampled: 09/10/2016 0928
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2026	
Prep Method: 200			Date Prepared:	09/16/2016 1250	
Pb	39.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 18 - Room 24 Fountain
Lab Sample ID: 420-110105-18

Date Sampled: 09/10/2016 0928
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	2036	
			Date Prepared:	09/16/2016	1353	
	19.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 19 - Room 23 Sink
Lab Sample ID: 420-110105-19

Date Sampled: 09/10/2016 0930
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2051	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	25.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 20 - Room 23 Fountain
Lab Sample ID: 420-110105-20

Date Sampled: 09/10/2016 0930
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2054	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	1.35	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 21 - Girls Bathroom by Rm 23 Sink 1
Lab Sample ID: 420-110105-21

Date Sampled: 09/10/2016 0933
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2058	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	7.49	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 22 - Girls Bathroom by Rm 23 Sink 2
Lab Sample ID: 420-110105-22

Date Sampled: 09/10/2016 0933
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2101	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	3.19	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 23 - Slop Sink by Room 23
Lab Sample ID: 420-110105-23

Date Sampled: 09/10/2016 0935
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2105	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	39.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 24 - Room 25 Sink
Lab Sample ID: 420-110105-24

Date Sampled: 09/10/2016 0937
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016	2108	
Prep Method: 200			Date Prepared:	09/16/2016	1353	
Pb	75.7	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 25 - Room 25 Fountain
Lab Sample ID: 420-110105-25

Date Sampled: 09/10/2016 0937
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/21/2016 1223	
Prep Method: 200			Date Prepared:	09/19/2016 1100	
Pb	3.32	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 26 - Room 27 Sink
Lab Sample ID: 420-110105-26

Date Sampled: 09/10/2016 0938
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/21/2016	1228	
			Date Prepared:	09/19/2016	1100	
	112	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 27 - Room 27 Fountain
Lab Sample ID: 420-110105-27

Date Sampled: 09/10/2016 0938
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/21/2016 1233	
Prep Method: 200				Date Prepared:	09/19/2016 1100	
Pb	17.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 28 - Boys Bathroom by Room 25 Sink 1
Lab Sample ID: 420-110105-28

Date Sampled: 09/10/2016 0941
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2119	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	3.07	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 29 - Boys Bathroom by Room 25 Sink 2
Lab Sample ID: 420-110105-29

Date Sampled: 09/10/2016 0941
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2122	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	4.46	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 30 - Room 29 Sink
Lab Sample ID: 420-110105-30

Date Sampled: 09/10/2016 0943
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016	2126	
Prep Method: 200			Date Prepared:	09/16/2016	1353	
Pb	20.7	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 31 - Room 29 Fountain
Lab Sample ID: 420-110105-31

Date Sampled: 09/10/2016 0943
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed: 09/16/2016 2130			
Prep Method: 200		Date Prepared: 09/16/2016 1353			
Pb	1.81	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 32 - Room 26 Sink
Lab Sample ID: 420-110105-32

Date Sampled: 09/10/2016 0947
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2133	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	646 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 33 - Room 26 Fountain
Lab Sample ID: 420-110105-33

Date Sampled: 09/10/2016 0947
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	2137	
			Date Prepared:	09/16/2016	1353	
	46.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 34 - Room 30 Sink
Lab Sample ID: 420-110105-34

Date Sampled: 09/10/2016 0949
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016	2140	
Prep Method: 200			Date Prepared:	09/16/2016	1353	
Pb	29.1	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 35 - Room 30 Fountain
Lab Sample ID: 420-110105-35

Date Sampled: 09/10/2016 0949
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2144	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	4.44	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 36 - Room 31 Sink
Lab Sample ID: 420-110105-36

Date Sampled: 09/10/2016 0950
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016	2147	
Prep Method: 200			Date Prepared:	09/16/2016	1353	
Pb	26.5	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 37 - Room 31 Fountain
Lab Sample ID: 420-110105-37

Date Sampled: 09/10/2016 0950
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2151	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	2.12	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 38 - Room 33 Sink
Lab Sample ID: 420-110105-38

Date Sampled: 09/10/2016 0955
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2201	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	5.17	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 39 - Room 33 Fountain
Lab Sample ID: 420-110105-39

Date Sampled: 09/10/2016 0955
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2205	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 40 - Room 35 Sink
Lab Sample ID: 420-110105-40

Date Sampled: 09/10/2016 0957
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2209	
Prep Method: 200			Date Prepared:	09/16/2016 1353	
Pb	2.50	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 41 - Room 35 Fountain
Lab Sample ID: 420-110105-41

Date Sampled: 09/10/2016 0957
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	2216	
			Date Prepared:	09/16/2016	1455	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 42 - Room 37 Sink
Lab Sample ID: 420-110105-42

Date Sampled: 09/10/2016 0959
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2230	
Prep Method: 200			Date Prepared:	09/16/2016 1455	
Pb	3.49	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 43 - Room 37 Fountain
Lab Sample ID: 420-110105-43

Date Sampled: 09/10/2016 0059
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	2233	
			Date Prepared:	09/16/2016	1455	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 44 - Room 32 Sink
Lab Sample ID: 420-110105-44

Date Sampled: 09/10/2016 1001
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2244	
Prep Method: 200			Date Prepared:	09/16/2016 1455	
Pb	3.25	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 45 - Room 32 Fountain
Lab Sample ID: 420-110105-45

Date Sampled: 09/10/2016 1001
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	2248	
			Date Prepared:	09/16/2016	1455	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 46 - Room 39 Sink
Lab Sample ID: 420-110105-46

Date Sampled: 09/10/2016 1002
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2251	
Prep Method: 200			Date Prepared:	09/16/2016 1455	
Pb	2.28	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 47 - Room 39 Fountain
Lab Sample ID: 420-110105-47

Date Sampled: 09/10/2016 1002
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	2255	
			Date Prepared:	09/16/2016	1455	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 48 - Room 34 Sink
Lab Sample ID: 420-110105-48

Date Sampled: 09/10/2016 1003
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2258	
Prep Method: 200			Date Prepared:	09/16/2016 1455	
Pb	2.41	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 49 - Room 34 Fountain
Lab Sample ID: 420-110105-49

Date Sampled: 09/10/2016 1003
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	2302	
			Date Prepared:	09/16/2016	1455	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 50 - Left Fountain by Room 34
Lab Sample ID: 420-110105-50

Date Sampled: 09/10/2016 1005
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2305	
Prep Method: 200			Date Prepared:	09/16/2016 1455	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 51 - Right Fountain by Room 34
Lab Sample ID: 420-110105-51

Date Sampled: 09/10/2016 1005
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/16/2016 2309	
Prep Method: 200				Date Prepared:	09/16/2016 1455	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 52 - Room 46 Sink
Lab Sample ID: 420-110105-52

Date Sampled: 09/10/2016 1008
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2312	
Prep Method: 200			Date Prepared:	09/16/2016 1455	
Pb	2.88	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 53 - Room 46 Fountain
Lab Sample ID: 420-110105-53

Date Sampled: 09/10/2016 1008
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	2316	
			Date Prepared:	09/16/2016	1455	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 54 - Room 47 Sink
Lab Sample ID: 420-110105-54

Date Sampled: 09/10/2016 1011
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2327	
Prep Method: 200			Date Prepared:	09/16/2016 1455	
Pb	2.45	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 55 - Room 47 Fountain
Lab Sample ID: 420-110105-55

Date Sampled: 09/10/2016 1011
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	2330	
			Date Prepared:	09/16/2016	1455	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 56 - Room 48 Sink
Lab Sample ID: 420-110105-56

Date Sampled: 09/10/2016 1013
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2334	
Prep Method: 200			Date Prepared:	09/16/2016 1455	
Pb	3.26	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 57 - Room 48 Fountain
Lab Sample ID: 420-110105-57

Date Sampled: 09/10/2016 1013
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	2337	
			Date Prepared:	09/16/2016	1455	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 58 - Room 49 Sink
Lab Sample ID: 420-110105-58

Date Sampled: 09/10/2016 1016
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed: 09/16/2016 2341			
Prep Method: 200		Date Prepared: 09/16/2016 1455			
Pb	2.12	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 59 - Room 49 Fountain
Lab Sample ID: 420-110105-59

Date Sampled: 09/10/2016 1016
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/16/2016 2344	
Prep Method: 200				Date Prepared:	09/16/2016 1455	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 60 - Room 50 Sink
Lab Sample ID: 420-110105-60

Date Sampled: 09/10/2016 1017
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/16/2016 2348	
Prep Method: 200			Date Prepared:	09/16/2016 1455	
Pb	1.12	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 61 - Room 50 Fountain
Lab Sample ID: 420-110105-61

Date Sampled: 09/10/2016 1017
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/16/2016	2352	
			Date Prepared:	09/16/2016	1529	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 62 - Room 51 Sink
Lab Sample ID: 420-110105-62

Date Sampled: 09/10/2016 1019
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0013	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	2.49	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 63 - Room 51 Fountain
Lab Sample ID: 420-110105-63

Date Sampled: 09/10/2016 1019
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0017	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	1.77	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 64 - Room 52 Sink
Lab Sample ID: 420-110105-64

Date Sampled: 09/10/2016 1022
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/17/2016 0020	
Prep Method: 200				Date Prepared:	09/16/2016 1529	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 65 - Room 52 Fountain
Lab Sample ID: 420-110105-65

Date Sampled: 09/10/2016 1022
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/17/2016	0024	
			Date Prepared:	09/16/2016	1529	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 66 - Room 53 Sink
Lab Sample ID: 420-110105-66

Date Sampled: 09/10/2016 1024
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0027	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	2.30	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 67 - Room 53 Sink
Lab Sample ID: 420-110105-67

Date Sampled: 09/10/2016 1024
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/17/2016 0031	
Prep Method: 200				Date Prepared:	09/16/2016 1529	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 68 - Girls Bathroom by Rm 52 Sink 1
Lab Sample ID: 420-110105-68

Date Sampled: 09/10/2016 1025
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0034	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	2.32	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 69 - Girls Bathroom by Rm 52 Sink 2
Lab Sample ID: 420-110105-69

Date Sampled: 09/10/2016 1025
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0038	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	3.86	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 70 - Boys Bathroom by Rm 52 Sink 1
Lab Sample ID: 420-110105-70

Date Sampled: 09/10/2016 1027
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0042	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	4.41	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 71 - Boys Bathroom by Rm 52 Sink 2
Lab Sample ID: 420-110105-71

Date Sampled: 09/10/2016 1027
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0052	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	6.85	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 72 - Boys Bathroom by Rm 52 Sink 3
Lab Sample ID: 420-110105-72

Date Sampled: 09/10/2016 1027
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0056	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	2.22	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 73 - Left Fountain by 61B
Lab Sample ID: 420-110105-73

Date Sampled: 09/10/2016 1030
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/17/2016 0059	
Prep Method: 200				Date Prepared:	09/16/2016 1529	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 74 - Right Fountain by 61B
Lab Sample ID: 420-110105-74

Date Sampled: 09/10/2016 1030
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/17/2016 0103	
Prep Method: 200				Date Prepared:	09/16/2016 1529	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 75 - Room 61 Sink
Lab Sample ID: 420-110105-75

Date Sampled: 09/10/2016 1032
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0107	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	3.34	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 76 - Room 60 Sink
Lab Sample ID: 420-110105-76

Date Sampled: 09/10/2016 1033
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0110	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	1.66	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 77 - Room 60 Bathroom Sink
Lab Sample ID: 420-110105-77

Date Sampled: 09/10/2016 1034
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0114	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	7.53	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 78 - Boys Bathroom by Greeter Desk Sink 1
Lab Sample ID: 420-110105-78

Date Sampled: 09/10/2016 1043
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0117	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	8.49	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 79 - Boys Bathroom by Greeter Desk Sink 2
Lab Sample ID: 420-110105-79

Date Sampled: 09/10/2016 1043
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0121	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	2.99	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 80 - Office Left Bathroom Sink
Lab Sample ID: 420-110105-80

Date Sampled: 09/10/2016 1047
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 0124	
Prep Method: 200			Date Prepared:	09/16/2016 1529	
Pb	5.80	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 81 - Office Right Bathroom Sink
Lab Sample ID: 420-110105-81

Date Sampled: 09/10/2016 1047
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1611	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	6.63	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 82 - Nurse's Sink
Lab Sample ID: 420-110105-82

Date Sampled: 09/10/2016 1052
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1625	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	4.07	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 83 - Nurse's Bathroom Sink
Lab Sample ID: 420-110105-83

Date Sampled: 09/10/2016 1052
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1629	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	5.67	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 84 - Room 03 Sink
Lab Sample ID: 420-110105-84

Date Sampled: 09/10/2016 1054
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1632	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	30.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 85 - Room 03 Fountain
Lab Sample ID: 420-110105-85

Date Sampled: 09/10/2016 1054
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1636	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	1.08	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 86 - Room 02 Sink
Lab Sample ID: 420-110105-86

Date Sampled: 09/10/2016 1055
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/17/2016	1639	
			Date Prepared:	09/17/2016	0930	
	32.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 87 - Room 02 Fountain
Lab Sample ID: 420-110105-87

Date Sampled: 09/10/2016 1055
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1650	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	2.79	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 88 - Girls Bathroom by Rm 02 Sink 1
Lab Sample ID: 420-110105-88

Date Sampled: 09/10/2016 1058
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/17/2016	1653	
			Date Prepared:	09/17/2016	0930	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 89 - Girls Bathroom by Rm 02 Sink 2
Lab Sample ID: 420-110105-89

Date Sampled: 09/10/2016 1058
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb			Date Analyzed:	09/17/2016	1657	
			Date Prepared:	09/17/2016	0930	
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 90 - Girls Bathroom by Rm 02 Sink 3
Lab Sample ID: 420-110105-90

Date Sampled: 09/10/2016 1058
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1700	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	1.52	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 91 - Girls Bathroom by Rm 02 Sink 4
Lab Sample ID: 420-110105-91

Date Sampled: 09/10/2016 1058
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1704	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	1.59	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 92 - Custodial Slop Sink by Rm 04
Lab Sample ID: 420-110105-92

Date Sampled: 09/10/2016 1100
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1707	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	24.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 93 - Fountain by Room 04
Lab Sample ID: 420-110105-93

Date Sampled: 09/10/2016 1102
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1711	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	2.90	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 94 - Boys Bathroom by 5A Sink 1
Lab Sample ID: 420-110105-94

Date Sampled: 09/10/2016 1105
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1714	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	1.44	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 95 - Boys Bathroom by 5A Sink 2
Lab Sample ID: 420-110105-95

Date Sampled: 09/10/2016 1105
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/17/2016 1718	
Prep Method: 200				Date Prepared:	09/17/2016 0930	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 96 - Boys Bathroom by 5A Sink 3
Lab Sample ID: 420-110105-96

Date Sampled: 09/10/2016 1105
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1722	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	1.07	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 97 - Boys Bathroom by 5A Sink 4
Lab Sample ID: 420-110105-97

Date Sampled: 09/10/2016 1105
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1732	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	1.48	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 98 - Room 04 Sink
Lab Sample ID: 420-110105-98

Date Sampled: 09/10/2016 1107
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1736	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	30.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 99 - Room 04 Fountain
Lab Sample ID: 420-110105-99

Date Sampled: 09/10/2016 1107
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1739	
Prep Method: 200			Date Prepared:	09/17/2016 0930	
Pb	2.16	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 100 - Room 06 Sink
Lab Sample ID: 420-110105-100

Date Sampled: 09/10/2016 1110
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016	1743	
Prep Method: 200			Date Prepared:	09/17/2016	0930	
Pb	34.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 101 - Room 06 Fountain
Lab Sample ID: 420-110105-101

Date Sampled: 09/10/2016 1110
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1746	
Prep Method: 200			Date Prepared:	09/17/2016 1000	
Pb	1.28	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 102 - Room 07 Sink
Lab Sample ID: 420-110105-102

Date Sampled: 09/10/2016 1112
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016	1800	
Prep Method: 200			Date Prepared:	09/17/2016	1000	
Pb	36.0	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 103 - Room 07 Fountain
Lab Sample ID: 420-110105-103

Date Sampled: 09/10/2016 1112
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1804	
Prep Method: 200			Date Prepared:	09/17/2016 1000	
Pb	7.23	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 104 - Room 08 Sink
Lab Sample ID: 420-110105-104

Date Sampled: 09/10/2016 1113
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016	1814	
Prep Method: 200			Date Prepared:	09/17/2016	1000	
Pb	35.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 105 - Room 08 Fountain
Lab Sample ID: 420-110105-105

Date Sampled: 09/10/2016 1113
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1818	
Prep Method: 200			Date Prepared:	09/17/2016 1000	
Pb	3.63	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 106 - Room 09 Sink
Lab Sample ID: 420-110105-106

Date Sampled: 09/10/2016 1115
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1821	
Prep Method: 200			Date Prepared:	09/17/2016 1000	
Pb	20.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 107 - Room 09 Fountain
Lab Sample ID: 420-110105-107

Date Sampled: 09/10/2016 1115
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1825	
Prep Method: 200			Date Prepared:	09/17/2016 1000	
Pb	3.79	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 108 - Room 10 Sink
Lab Sample ID: 420-110105-108

Date Sampled: 09/10/2016 1118
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016	1828	
Prep Method: 200			Date Prepared:	09/17/2016	1000	
Pb	34.1	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 109 - Room 10 Fountain
Lab Sample ID: 420-110105-109

Date Sampled: 09/10/2016 1119
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1832	
Prep Method: 200			Date Prepared:	09/17/2016 1000	
Pb	2.81	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 110 - Room 11 Sink
Lab Sample ID: 420-110105-110

Date Sampled: 09/10/2016 1120
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1835	
Prep Method: 200			Date Prepared:	09/17/2016 1000	
Pb	46.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 111 - Room 12 Sink
Lab Sample ID: 420-110105-111

Date Sampled: 09/10/2016 1122
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1839	
Prep Method: 200			Date Prepared:	09/17/2016 1000	
Pb	27.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110105-1
Sdg Number: Pine Bush CSD - EJR

Client Sample ID: 112 - Room 12 Fountain
Lab Sample ID: 420-110105-112

Date Sampled: 09/10/2016 1122
Date Received: 09/13/2016 1144
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/17/2016 1842	
Prep Method: 200			Date Prepared:	09/17/2016 1000	
Pb	6.18	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:
Sdg Number: Pine Bush CSD - EJR

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Pine Bush CSD - EJR

The following analytes are Not Part of the ELAP scope of accreditation

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalien Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture) , Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Pine Bush CSD - EJR

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points

Meredith Ruthven

From: Degraw, Jack <john.degraw@ouboces.org>
Sent: Wednesday, September 14, 2016 12:09 PM
To: Meredith Ruthven
Subject: Re: Discrepancies Between COC and Sample Bottles

Sorry for the confusion. The bottles are all labeled correctly.

Jack

On Wed, Sep 14, 2016 at 9:01 AM, Meredith Ruthven <mruthven@envirotestlaboratories.com> wrote:

Hi Jack,

The samples received yesterday had a couple of discrepancies between the COC and the Sample bottles see below:

110105 (Orange-Ulster BOCES – Pine Bush CSD – EJR):

#12: CoC says "Room 15," Bottle says "Room 18."

#65: CoC says "Room 52 Sink," Bottle says "Room 52 Fountain."

#90: CoC says "Sink 2," Bottle says "Sink 3."

Let me know which are the correct IDs.

Thanks,

Meredith

Meredith Ruthven

EnviroTest
Laboratories Inc.

315 Fullerton Avenue | Newburgh, NY 12550 | Phone: (845)562-0890

mruthven@envirotestlaboratories.com

CONFIDENTIALITY NOTICE: This email transmission may contain confidential and/or legally privileged information from EnviroTest Laboratories, Inc. intended only for the use of the individual(s) named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of this information or the taking of any action in reliance on the contents of this email transmission is strictly prohibited. If you have received this transmission in error, please contact the sender immediately and delete the material from any computer.

--

Jack DeGraw
Health and Safety Coordinator
Orange - Ulster BOCES
53 Gibson Rd.
Goshen, NY 10924
845-781-4887

169



EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

REPORT# (Lab Use Only)

110105

PROJECT REFERENCE: Pine Bush CSD - EJR

ENVIROTEST PROJECT MANAGER: Debra Bayer

CLIENT (SITE) PM: Jack DeGraw

CLIENT NAME: Orange-Ulster BOCES

CLIENT ADDRESS: 53 Gibson Road, Goshen, NY 10924

COMPANY CONTRACTING THIS WORK (if applicable):

Lab Name: EnviroTest Laboratories

Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT NO.:

P.O. NUMBER:

CLIENT PHONE: 845-781-4887

CLIENT FAX:

christy.fischer.outboces.org

PROJECT LOCATION:

TOWN:

CLIENT FAX:

MATRIX TYPE:

OTHER SPECIFY:

SOLID OR SEMISOLID:

D (Drinking Water) or W (Waste Water) Indicate:

AQUEOUS (WATER):

COMPOSITE (C) OR GRAB (G) INDICATE:

REQUIRED ANALYSES:

40ml Vials HCl

Liter Amber HCl

250ml Plastic Nitric Acid

250ml Plastic Sulfuric Acid

Liter Plastic

250ml Plastic

Terra Core

Other

Other

SAMPLE IDENTIFICATION		DATE		TIME		SAMPLE		DATE		TIME		REMARKS	
9/10/2016	9:05	1- Girls Bathroom by Boiler Room Sink 1	9/10/2016	9:05	1- Girls Bathroom by Boiler Room Sink 1	9/10/2016	9:05	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:05	2- Girls Bathroom by Boiler Room Sink 2	9/10/2016	9:05	2- Girls Bathroom by Boiler Room Sink 2	9/10/2016	9:05	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:07	3 - Custodial Slop Sink By Cafeteria	9/10/2016	9:07	3 - Custodial Slop Sink By Cafeteria	9/10/2016	9:07	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:10	4 - Room 132 Bathroom Sink	9/10/2016	9:10	4 - Room 132 Bathroom Sink	9/10/2016	9:10	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:15	5 - Kitchen Left Sink	9/10/2016	9:15	5 - Kitchen Left Sink	9/10/2016	9:15	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:15	6 - Kitchen Right Sink	9/10/2016	9:15	6 - Kitchen Right Sink	9/10/2016	9:15	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:17	7 - Kitchen Hand Sink	9/10/2016	9:17	7 - Kitchen Hand Sink	9/10/2016	9:17	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:19	8 - Kitchen Bathroom Sink	9/10/2016	9:19	8 - Kitchen Bathroom Sink	9/10/2016	9:19	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:20	9 - Fountain by Cafeteria	9/10/2016	9:20	9 - Fountain by Cafeteria	9/10/2016	9:20	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:21	10 - Room 36 Sink	9/10/2016	9:21	10 - Room 36 Sink	9/10/2016	9:21	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:22	11- Room 18 Sink	9/10/2016	9:22	11- Room 18 Sink	9/10/2016	9:22	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:22	12 - Room 15 Fountain	9/10/2016	9:22	12 - Room 15 Fountain	9/10/2016	9:22	1	1	1	1	Lead (DW 200.8)	
9/10/2016	9:25	13 Room 20 Sink	9/10/2016	9:25	13 Room 20 Sink	9/10/2016	9:25	1	1	1	1	Lead (DW 200.8)	

RELINQUISHED BY: (SIGNATURE) *Debra Bayer*

SAMPLED BY: (SIGNATURE) *Debra Bayer*

RELINQUISHED BY: (SIGNATURE) *Munroe P. DeGraw*

DATE: 9/13/16

DATE: 9/14/16

DATE: 9/13/16

COMPANY: outboces

COMPANY: outboces

COMPANY: outboces

RECEIVED FOR LABORATORY BY: (SIGNATURE) *A. Elmendorf*

DATE: 9/13/16

TIME: 1144

COOLER TEMP (C): 21.9°C

CUSTODY INTACT: YES

NO

LABORATORY REMARKS: ICE (Y) ☒ CL2 ☒

Reviewed by: *IR #3*

269

EnviroTest Laboratories, Inc.



CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

110105

PROJECT REFERENCE		PROJECT NO.	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES								PAGE 1 of 1							
ENVIROTEST PROJECT MANAGER		P.O. NUMBER	TOWN	OTHER SPECIFY	AQUEOUS (WATER)	D (Drinking Water) or V (Waste Water) Indicate	SOLID OR SEMISOLID	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	TURNAROUND TIME		
CLIENT (SITE) PM	CLIENT PHONE	CLIENT FAX																		
CLIENT NAME	Orange-Ulster BOCES	christy.fischer@outpoces.org																		
CLIENT ADDRESS	53 Gibson Road, Goshen, NY 10924																			
COMPANY CONTRACTING THIS WORK (if applicable):																				
SAMPLE		SAMPLE IDENTIFICATION																		
DATE	TIME																			
9/10/2016	9:25	14 - Room 20 Fountain																		
9/10/2016	9:27	15 - Room 22 Sink																		
9/10/2016	9:27	16 - Room 22 Fountain																		
9/10/2016	9:28	17 Room 24 Sink																		
9/10/2016	9:28	18 Room 24 Fountain																		
9/10/2016	9:30	19Room 23 Sink																		
9/10/2016	9:30	20 Room 23 Fountain																		
9/10/2016	9:33	21 Girls Bathroom by Rm 23 Sink 1																		
9/10/2016	9:33	22 Girls Bathroom by Rm 23 Sink 2																		
9/10/2016	9:35	23 Slop Sink by Room 23																		
9/10/2016	9:37	24 Room 25 Sink																		
9/10/2016	9:37	25 Room 25 Fountain																		
9/10/2016	9:38	26 Room 27 Sink																		
RELINQUISHED BY: (SIGNATURE)		DATE	9/13/16	TIME	10:01	RECEIVED BY: (SIGNATURE)													COMPADATE	TIME
SAMPLE BY: (SIGNATURE)		DATE	9/13/16	TIME	11:22	RECEIVED BY: (SIGNATURE)													COMPADATE	TIME
RELINQUISHED BY: (SIGNATURE)		DATE	9/13/16	TIME	9:25	RECEIVED BY: (SIGNATURE)													COMPADATE	TIME
Travis G. DeLong		DATE	9/13/16	TIME	11:44	RECEIVED BY: (SIGNATURE)													COMPADATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	9/13/16	TIME	1144	CUSTODY INTACT	YES	NO	Cooler Temp(C):	21.9°C	LABORATORY REMARKS:	ICE Y N ☒ pH ☒ Cl2	Reviewed by
A. Elmendorf	DATE	9/13/16	TIME	1144	YES							

IR #3



EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

REPORT# (Lab Use Only)

110105

Lab Name EnviroTest Laboratories
Address & Phone 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Pine Bush CSD - EJR		PROJECT NO.	PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES							PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		OTHER SPECIFY		Other							TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX		AQUEOUS (WATER)		250ml Plastic Nitric Acid								
CLIENT NAME Orange-Ulster BOCES		christy.fischer.oubooces.org		COMPOSITE (C) OR GRAB (G) INDICATE		40ml Amber HCl									
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924		COMPANY CONTRACTING THIS WORK (if applicable)		SAMPLE IDENTIFICATION		D (Drinking Water) or W (Waste Water) Indicate		250ml Plastic Sulfuric Acid							#OF COOLERS
						SOLID OR SEMISOLID		Liter Plastic							
						OTHER SPECIFY		250ml Plastic Nitric Acid							
DATE	TIME	SAMPLE		DATE		TIME	COMPOSITE (C) OR GRAB (G) INDICATE	40ml Amber HCl							REMARKS
9/10/2016	9:38	27 - Room 27 Fountain		9/13/16		10:40	G	1							
9/10/2016	9:41	28 Boys Bathroom by Room 25 Sink 1		9/10/16		11:22	G	1							
9/10/2016	9:41	29 Boys Bathroom by Room 25 Sink 2		9/10/16		9:58	G	1							
9/10/2016	9:43	30 - Room 29 Sink		9/10/16		9:58	G	1							
9/10/2016	9:43	31 - Room 29 Fountain32		9/10/16		9:58	G	1							
9/10/2016	9:47	32 Room 26 Sink		9/10/16		9:58	G	1							
9/10/2016	9:47	33 Room 26 Fountain		9/10/16		9:58	G	1							
9/10/2016	9:49	34 room 30 Sink		9/10/16		9:58	G	1							
9/10/2016	9:49	35 Room 30 Fountain		9/10/16		9:58	G	1							
9/10/2016	9:50	36 Room 31 Sink		9/10/16		9:58	G	1							
9/10/2016	9:50	37 Room 31 Fountain		9/10/16		9:58	G	1							
9/10/2016	9:55	38 room 33 Sink		9/10/16		9:58	G	1							
9/10/2016	9:55	39 Room 33 Fountain		9/10/16		9:58	G	1							
RELINQUISHED BY: (SIGNATURE)		DATE		DATE		TIME	RECEIVED BY: (SIGNATURE)	COMPADATE							
SAMPLED BY: (SIGNATURE)		DATE		DATE		TIME	RECEIVED BY: (SIGNATURE)	COMPADATE							
RELINQUISHED BY: (SIGNATURE)		DATE		DATE		TIME	RECEIVED BY: (SIGNATURE)	COMPADATE							

RECEIVED FOR LABORATORY BY: (SIGNATURE)		DATE	TIME	CUSTODY INTACT	Cooler Temp(C):	LABORATORY REMARKS:	
A. Elmendorf		9/13/16	1144	YES	21.9°C	ICE (Y) N () pH () Cl2 ()	
				NO			

IR#3



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

110105

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Pine Bush CSD - EJR		PROJECT NO.	PROJECT LOCATION		MATRIX TYPE	REQUIRED ANALYSES								PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		OTHER SPECIFY	☐ 40ml Amber HCl ☐ 250ml Plastic Nitric Acid ☐ 250ml Plastic Sulfuric Acid ☐ Liter Plastic ☐ 250ml Plastic ☐ Terra Core ☐ Other ☐ Other								TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX												
CLIENT NAME Orange-Ulster BOCES		christy.fischer.oubores.org													
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924															
COMPANY CONTRACTING THIS WORK (if applicable):															
SAMPLE		TIME		SAMPLE IDENTIFICATION		COMPOSITE (C) OR GRAB (G) INDICATE		AQUEOUS (WATER)		D (Drinking Water) or W (Waste Water) Indicate		NUMBER OF CONTAINERS SUBMITTED		REMARKS	
DATE	TIME														
9/10/2016	9:57			40 Room 35 Sink	G	D						1			Lead (DW 200.8)
9/10/2016	9:57			41 - Room 35 Fountain	G	D						1			Lead (DW 200.8)
9/10/2016	9:59			42 - Room 37 Sink	G	D						1			Lead (DW 200.8)
9/10/2016	0:59			43 Room 37 Fountain	G	D						1			Lead (DW 200.8)
9/10/2016	10:01			44 Room 32 Sink	G	D						1			Lead (DW 200.8)
9/10/2016	10:01			45 Room 32 Fountain	G	D						1			Lead (DW 200.8)
9/10/2016	10:02			46 Room 39 Sink	G	D						1			Lead (DW 200.8)
9/10/2016	10:02			47 Room 39 fountain	G	D						1			Lead (DW 200.8)
9/10/2016	10:03			48 - room 34 Sink	G	D						1			Lead (DW 200.8)
9/10/2016	10:03			49 - Room 34 Fountain	G	D						1			Lead (DW 200.8)
9/10/2016	10:05			50 - Left fountain by Room 34	G	D						1			Lead (DW 200.8)
9/10/2016	10:05			51 Right Fountain by Room 34	G	D						1			Lead (DW 200.8)
9/10/2016	10:08			52 Room 46 Sink	G	D						1			Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE)		DATE		COMPANY		TIME		RECEIVED BY: (SIGNATURE)		COMP. DATE		TIME			
<i>Debra Bayer</i>		9/13/16		oubores		10:00		<i>Debra Bayer</i>		9/13-16					
SAMPLER BY: (SIGNATURE)		DATE		COMPANY		TIME		RECEIVED BY: (SIGNATURE)		COMP. DATE		TIME			
<i>Debra Bayer</i>		9/10/16		oubores		9:57		<i>Debra Bayer</i>		9/13-16					
RELINQUISHED BY: (SIGNATURE)		DATE		COMPANY		TIME		RECEIVED BY: (SIGNATURE)		COMP. DATE		TIME			
<i>Travis S. Debra</i>		9/13/16		oubores		11:44		<i>Travis S. Debra</i>		9/13-16					
RECEIVED FOR LABORATORY BY: (SIGNATURE)		DATE		TIME		CUSTODY INTACT		Cooler Temp (C):		LABORATORY REMARKS:		ICE (Y/N) PH CL2		Reviewed by	
<i>Debra Bayer</i>		9/13/16		1144		YES		21.9°C							
IR#3															



CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)


110105

PROJECT REFERENCE Pine Bush CSD - EJR		PROJECT NO.	PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES						PAGE 1 of 1
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	OTHER SPECIFY		40ml Vials HCl 250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid 250ml Plastic Terra Core Other Other						TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX	AQUEOUS (WATER)		Total # of Containers 40ml Vials HCl 250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid 250ml Plastic Terra Core Other Other						NORMAL	
CLIENT NAME Orange-Ulster BOCES		christy.fischer.oubores.org		COMPOSITE (C) OR GRAB (G) INDICATE		NUMBER OF CONTAINERS SUBMITTED						QUICK	
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924				SOLID OR SEMISOLID		REMARKS						VERBAL	
COMPANY CONTRACTING THIS WORK (if applicable)				D (Drinking Water) or V (Waste Water) Indicate								# OF COOLERS	
SAMPLE		TIME		DATE									
9/10/2016		10:08		53 Room 46 Fountain		G						Lead (DW 200.8)	
9/10/2016		10:11		54 - Room 47 Sink		G						Lead (DW 200.8)	
9/10/2016		10:11		55 - Room 47 fountain		G						Lead (DW 200.8)	
9/10/2016		10:13		56 Room 48 Sink		G						Lead (DW 200.8)	
9/10/2016		10:13		57 Room 48 fountain		G						Lead (DW 200.8)	
9/10/2016		10:16		58 - Room 49 Sink		G						Lead (DW 200.8)	
9/10/2016		10:16		59 - Room 49 fountain		G						Lead (DW 200.8)	
9/10/2016		10:17		60 Room 50 Sink		G						Lead (DW 200.8)	
9/10/2016		10:17		61 Room 50 Fountain		G						Lead (DW 200.8)	
9/10/2016		10:19		62 Room 51 Sink		G						Lead (DW 200.8)	
9/10/2016		10:19		63 Room 51 Fountain		G						Lead (DW 200.8)	
9/10/2016		10:22		64 Room 52 Sink mine 9/14/16 as per 5.10.16		G						Lead (DW 200.8)	
9/10/2016		10:22		65 - Room 52 Sink Fountain		G						Lead (DW 200.8)	
RELINQUISHED BY: (SIGNATURE) <i>[Signature]</i>		DATE 9/13/16		COMPANY oubores		RECEIVED BY: (SIGNATURE) TIME 10:00						COMP DATE	
SAMPLED BY: (SIGNATURE) <i>[Signature]</i>		DATE 9/13/16		COMPANY oubores		RECEIVED BY: (SIGNATURE) TIME 11:22						COMP DATE	
RELINQUISHED BY: (SIGNATURE) <i>[Signature]</i>		DATE 9/13/16		COMPANY oubores		RECEIVED BY: (SIGNATURE) TIME 11:44						COMP DATE	
RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>[Signature]</i>		DATE 9/13/16		CUSTODY INTACT YES NO		LABORATORY REMARKS: ICE (Y) N () PH CL2						Revised by	

IR #3

6 of 9

EnviroTest Laboratories, Inc.



CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

110105

PROJECT REFERENCE		PROJECT NO.		PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES						PAGE 1 of 1	
Pine Bush CSD - EJR		P.O. NUMBER		TOWN		OTHER Specify		40ml Vials HCl Liter Amber HCl 250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid Liter Plastic 250ml Plastic Terra Core Other Other						1	
ENVIROTEST PROJECT MANAGER		CLIENT PHONE		CLIENT FAX		ACQUEOUS (WATER)		NUMBER OF CONTAINERS SUBMITTED						TURNAROUND TIME	
Debra Bayer		845-781-4887				D (Drinking Water) or V (Waste Water) Indicate		Total # of Containers						NORMAL	
CLIENT (SITE) PM		CLIENT NAME		CLIENT ADDRESS		COMPOSITE (C) OR GRAB (G) INDICATE		# OF COOLERS						QUICK	
Jack DeGraw		Orange-Ulster BOCES		53 Gibson Road, Goshen, NY 10924		SOLID OR SEMISOLID		REMARKS						VERBAL	
COMPANY CONTRACTING THIS WORK (If applicable)		SAMPLE		SAMPLE IDENTIFICATION		DATE									
		DATE		TIME											
		9/10/2016		10:24		66 - Room 53 Sink								Lead (DW 200.8)	
		9/10/2016		10:24		67 - Room 53 Fountain								Lead (DW 200.8)	
		9/10/2016		10:25		68 - Girls Bathroom by Rm 52 Sink 1								Lead (DW 200.8)	
		9/10/2016		10:25		69 - Girls Bathroom by Rm 52 Sink 2								Lead (DW 200.8)	
		9/10/2016		10:27		70 - Boys Bathroom by Rm 52 sink 1								Lead (DW 200.8)	
		9/10/2016		10:27		71 - Boys Bathroom by Rm 52 sink 2								Lead (DW 200.8)	
		9/10/2016		10:27		72 - Boys Bathroom by Rm 52 sink 3								Lead (DW 200.8)	
		9/10/2016		10:30		73 - Left fountain by 61B								Lead (DW 200.8)	
		9/10/2016		10:30		74 - Right fountain by 61B								Lead (DW 200.8)	
		9/10/2016		10:32		75 - Room 61 Sink								Lead (DW 200.8)	
		9/10/2016		10:33		76 - Room 60 Sink								Lead (DW 200.8)	
		9/10/2016		10:34		77 - Room 60 Bathroom Sink								Lead (DW 200.8)	
		9/10/2016		10:43		78 - Boys Bathroom by Greeter Desk Sink 1								Lead (DW 200.8)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY: (SIGNATURE)						TIME	
<i>[Signature]</i>		9/13/16		10:00		EnviroTest		RECEIVED BY: (SIGNATURE)						TIME	
SAMPLED BY: (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY: (SIGNATURE)						TIME	
<i>[Signature]</i>		9/10/16		11:29		EnviroTest		RECEIVED BY: (SIGNATURE)						TIME	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY: (SIGNATURE)						TIME	
<i>[Signature]</i>		9/13/16		11:44		EnviroTest		RECEIVED BY: (SIGNATURE)						TIME	
RECEIVED FOR LABORATORY BY: (SIGNATURE)		DATE		TIME		CUSTODY INTACT		LABORATORY REMARKS: ICE (Y) N () pH () CL2 ()						Reviewed by	
<i>[Signature]</i>		9/13/16		11:44		YES NO		21.9°C						IR #3	

7 of 9

CHAIN OF CUSTODY										REPORT# (Lab Use Only)																																																																																																																																																																																																																			
EnviroTest Laboratories, Inc.										110105																																																																																																																																																																																																																			
Lab Name: EnviroTest Laboratories Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890																																																																																																																																																																																																																													
PROJECT REFERENCE	Pine Bush CSD - EJR	PROJECT NO.		PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES		PAGE 1 of	1																																																																																																																																																																																																																		
ENVIROTEST PROJECT MANAGER	Debra Bayer	P.O. NUMBER		TOWN				40ml Vials HCl		TURNAROUND TIME																																																																																																																																																																																																																			
CLIENT (SITE) PM	Jack DeGraw	CLIENT PHONE	845-781-4887	CLIENT FAX				Liter Plastic		NORMAL																																																																																																																																																																																																																			
CLIENT NAME	Orange-Ulster BOCES	christy.fischer@oubooces.org						250ml Plastic Sulfuric Acid		QUICK																																																																																																																																																																																																																			
CLIENT ADDRESS	53 Gibson Road, Goshen, NY 10924							250ml Plastic Nitric Acid		VERBAL																																																																																																																																																																																																																			
COMPANY CONTRACTING THIS WORK (If applicable):																																																																																																																																																																																																																													
<table border="1"> <thead> <tr> <th colspan="2">SAMPLE</th> <th colspan="2">TIME</th> <th colspan="2">SAMPLE IDENTIFICATION</th> <th colspan="2">COMPOSITE (C) OR GRAB (G) INDICATE</th> <th colspan="2">OTHER SPECIES</th> <th colspan="2">NUMBER OF CONTAINERS SUBMITTED</th> <th colspan="2">REMARKS</th> </tr> <tr> <th>DATE</th> <th>TIME</th> <th>DATE</th> <th>TIME</th> <th>DATE</th> <th>TIME</th> <th>DATE</th> <th>TIME</th> <th>DATE</th> <th>TIME</th> <th>DATE</th> <th>TIME</th> <th>DATE</th> <th>TIME</th> </tr> </thead> <tbody> <tr> <td>9/10/2016</td> <td>10:43</td> <td>79 - Boys Bathroom by Greeter Desk Sink 2</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:47</td> <td>80 - Office Left bathroom Sink</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:47</td> <td>81 - Office right bathroom Sink</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:52</td> <td>82 - Nurse's Sink</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:52</td> <td>83 - Nurse's Bathroom Sink</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:54</td> <td>84 - Room 03 Sink</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:54</td> <td>85 - Room 03 fountain</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:55</td> <td>86 - Room 02 Sink</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:55</td> <td>87 - Room 02 fountain</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:58</td> <td>88 - Girls Bathroom by Rm 02 Sink 1</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:58</td> <td>89 - Girls Bathroom by Rm 02 Sink 2</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:58</td> <td>90 - Girls Bathroom by Rm 02 Sink #3</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> <tr> <td>9/10/2016</td> <td>10:58</td> <td>91 - Girls Bathroom by Rm 02 Sink 4</td> <td></td> <td>G</td> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>1</td> <td></td> <td>Lead (DW 200.8)</td> </tr> </tbody> </table>												SAMPLE		TIME		SAMPLE IDENTIFICATION		COMPOSITE (C) OR GRAB (G) INDICATE		OTHER SPECIES		NUMBER OF CONTAINERS SUBMITTED		REMARKS		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	9/10/2016	10:43	79 - Boys Bathroom by Greeter Desk Sink 2		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:47	80 - Office Left bathroom Sink		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:47	81 - Office right bathroom Sink		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:52	82 - Nurse's Sink		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:52	83 - Nurse's Bathroom Sink		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:54	84 - Room 03 Sink		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:54	85 - Room 03 fountain		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:55	86 - Room 02 Sink		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:55	87 - Room 02 fountain		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:58	88 - Girls Bathroom by Rm 02 Sink 1		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:58	89 - Girls Bathroom by Rm 02 Sink 2		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:58	90 - Girls Bathroom by Rm 02 Sink #3		G	D					1	1		Lead (DW 200.8)	9/10/2016	10:58	91 - Girls Bathroom by Rm 02 Sink 4		G	D					1	1		Lead (DW 200.8)
SAMPLE		TIME		SAMPLE IDENTIFICATION		COMPOSITE (C) OR GRAB (G) INDICATE		OTHER SPECIES		NUMBER OF CONTAINERS SUBMITTED		REMARKS																																																																																																																																																																																																																	
DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME																																																																																																																																																																																																																
9/10/2016	10:43	79 - Boys Bathroom by Greeter Desk Sink 2		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:47	80 - Office Left bathroom Sink		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:47	81 - Office right bathroom Sink		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:52	82 - Nurse's Sink		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:52	83 - Nurse's Bathroom Sink		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:54	84 - Room 03 Sink		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:54	85 - Room 03 fountain		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:55	86 - Room 02 Sink		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:55	87 - Room 02 fountain		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:58	88 - Girls Bathroom by Rm 02 Sink 1		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:58	89 - Girls Bathroom by Rm 02 Sink 2		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:58	90 - Girls Bathroom by Rm 02 Sink #3		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
9/10/2016	10:58	91 - Girls Bathroom by Rm 02 Sink 4		G	D					1	1		Lead (DW 200.8)																																																																																																																																																																																																																
RELINQUISHED BY: (SIGNATURE)				DATE: 9/13/16		TIME: 10:00		COMPANY: oubooces		RECEIVED BY: (SIGNATURE)		TIME																																																																																																																																																																																																																	
SAMPLED BY: (SIGNATURE)				DATE: 9/10/16		TIME: 11:22		COMPANY: oubooces		RECEIVED BY: (SIGNATURE)		TIME																																																																																																																																																																																																																	
RELINQUISHED BY: (SIGNATURE)				DATE: 9/13/16		TIME: 11:44		COMPANY: oubooces		RECEIVED BY: (SIGNATURE)		TIME																																																																																																																																																																																																																	
RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>Q. Amador</i> DATE: 9/13/16 TIME: 11:44 COMPANY: ETL																																																																																																																																																																																																																													
LABORATORY REMARKS: ICE (Y) ☒ No ☐ CL2 ☐ PH ☐ Cooler Temp (C): 21.9°C IR #3																																																																																																																																																																																																																													



EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

REPORT# (Lab Use Only)

110105

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT NO. _____
P.O. NUMBER _____
CLIENT PHONE: 845-781-4887
CLIENT FAX: _____
CLIENT (SITE) PM: Jack DeGraw
CLIENT NAME: Orange-Ulster BOCES
CLIENT ADDRESS: 53 Gibson Road, Goshen, NY 10924
COMPANY CONTRACTING THIS WORK (if applicable): _____

PROJECT LOCATION: _____
TOWN: _____
CLIENT FAX: _____
christy.fischer@oubooces.org

PROJECT REFERENCE		PROJECT NO.		PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES								PAGE 1 of 1			
Pine Bush CSD - EJR																			
ENVIROTEST PROJECT MANAGER		P.O. NUMBER		TOWN												TURNAROUND TIME			
Debra Bayer																			
CLIENT (SITE) PM		CLIENT PHONE		CLIENT FAX												NORMAL			
Jack DeGraw		845-781-4887														QUICK			
CLIENT NAME		CLIENT PHONE		CLIENT FAX												VERBAL			
Orange-Ulster BOCES																			
CLIENT ADDRESS		CLIENT PHONE		CLIENT FAX															
53 Gibson Road, Goshen, NY 10924																			
COMPANY CONTRACTING THIS WORK (if applicable):																			
SAMPLE		DATE		TIME		SAMPLE IDENTIFICATION		COMPOSITE (C) OR GRAB (G)		ACQUEOUS (WATER)		D (Drinking Water) or W (Waste Water) Indicate		OTHER SPECIFY		NUMBER OF CONTAINERS SUBMITTED		REMARKS	
9/10/2016		11:00				92 - Custodial Slop Sink by rm 04		G		D						1		Lead (DW 200.8)	
9/10/2016		11:02				93 - Fountain by room04		G		D						1		Lead (DW 200.8)	
9/10/2016		11:05				94 - Boys Bathroom by 5A Sink 1		G		D						1		Lead (DW 200.8)	
9/10/2016		11:05				95 - Boys Bathroom by 5A Sink 2		G		D						1		Lead (DW 200.8)	
9/10/2016		11:05				96 - Boys Bathroom by 5A Sink 3		G		D						1		Lead (DW 200.8)	
9/10/2016		11:05				97 - Boys Bathroom by 5A Sink 4		G		D						1		Lead (DW 200.8)	
9/10/2016		11:07				98 - Room 04 sink		G		D						1		Lead (DW 200.8)	
9/10/2016		11:07				99 - Room 04 Fountain		G		D						1		Lead (DW 200.8)	
9/10/2016		11:10				100 - Room 06 Sink		G		D						1		Lead (DW 200.8)	
9/10/2016		11:10				101 - Room 06 Fountain		G		D						1		Lead (DW 200.8)	
9/10/2016		11:12				102 Room 07 Sink		G		D						1		Lead (DW 200.8)	
9/10/2016		11:12				Room 07 Fountain		G		D						1		Lead (DW 200.8)	
9/10/2016		11:13				Room 08 Sink		G		D						1		Lead (DW 200.8)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY: (SIGNATURE)		DATE		TIME		COMPDATE		TIME			
<i>[Signature]</i>		9/13/16		11:00		oubooces		<i>[Signature]</i>		9/13/16		11:22		COMPDATE		TIME			
SAMPLER BY: (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY: (SIGNATURE)		DATE		TIME		COMPDATE		TIME			
<i>[Signature]</i>		9/10/16				oubooces		<i>[Signature]</i>		9/13-16				COMPDATE		TIME			
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		COMPANY		RECEIVED BY: (SIGNATURE)		DATE		TIME		COMPDATE		TIME			
<i>[Signature]</i>		9/13/16		11:44		oubooces		<i>[Signature]</i>		9/13/16		11:44		COMPDATE		TIME			

RECEIVED FOR LABORATORY BY: (SIGNATURE)

[Signature]

DATE

9/13/16

TIME

1144

COOLER Temp (C):

21.9°C

ICE (Y) ☒ NO ☐ pH

CL2

LABORATORY REMARKS:

IR#3

IR #3

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-110105-1
SDG Number: Pine Bush CSD - EJR

Login Number: 110105

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	21.9 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling. AE 9/13/16
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	False	Sample 12, 65, 90, see attched client email.
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	