

ANALYTICAL REPORT

Job Number: 420-110441-1

SDG Number: Pine Bush CSD-Pakanasink

Job Description: Orange-Ulster BOCES

For:

Orange-Ulster BOCES

53 Gibson Road

Goshen, NY 10924

Attention: Jack DeGraw



Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

10/03/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

Job Narrative
420-J110441-1

Comments

Results are compared to NYSDOH drinking water standards other federal regulations may apply.

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

Metals

No analytical or quality issues were noted.

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-110441-1
SDG Number: Pine Bush CSD-Pakanasink

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-110441-1
SDG Number: Pine Bush CSD-Pakanasink

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-110441-1
SDG Number: Pine Bush CSD-Pakanasink

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110441-1	1-Slop Sink by Loading dock	Drinking Water	09/14/2016 0502	09/19/2016 1510
420-110441-2	2-Kitchen Left Sink	Drinking Water	09/14/2016 0507	09/19/2016 1510
420-110441-3	3-Kitchen Right Sink	Drinking Water	09/14/2016 0507	09/19/2016 1510
420-110441-4	4-Kitchen Hand Sink	Drinking Water	09/14/2016 0508	09/19/2016 1510
420-110441-5	5-Cafeteria Fountain	Drinking Water	09/14/2016 0509	09/19/2016 1510
420-110441-6	6- Faculty Room Sink	Drinking Water	09/14/2016 0510	09/19/2016 1510
420-110441-7	7- Boys Bathroom Sink by Cafeteria	Drinking Water	09/14/2016 0512	09/19/2016 1510
420-110441-8	8-Girls Bathroom Sink by Cafeteria	Drinking Water	09/14/2016 0512	09/19/2016 1510
420-110441-9	9-Room 114 Sink	Drinking Water	09/14/2016 0514	09/19/2016 1510
420-110441-10	10-Room 114 Fountain	Drinking Water	09/14/2016 0514	09/19/2016 1510
420-110441-11	11-Room 118 Sink	Drinking Water	09/14/2016 0515	09/19/2016 1510
420-110441-12	12-Room 118 Fountain	Drinking Water	09/14/2016 0515	09/19/2016 1510
420-110441-13	13-Room 116 Sink	Drinking Water	09/14/2016 0516	09/19/2016 1510
420-110441-14	14-Room 116 Fountain	Drinking Water	09/14/2016 0516	09/19/2016 1510
420-110441-15	15-Room 172 Sink	Drinking Water	09/14/2016 0519	09/19/2016 1510
420-110441-16	16-Room 172 Fountain	Drinking Water	09/14/2016 0519	09/19/2016 1510
420-110441-17	17-Room 171 Sink	Drinking Water	09/14/2016 0520	09/19/2016 1510
420-110441-18	18-Room 171 Fountain	Drinking Water	09/14/2016 0520	09/19/2016 1510
420-110441-19	19-Room 170 Sink	Drinking Water	09/14/2016 0521	09/19/2016 1510
420-110441-20	20-Room 170 Fountain	Drinking Water	09/14/2016 0521	09/19/2016 1510
420-110441-21	21-Room 169 Sink	Drinking Water	09/14/2016 0522	09/19/2016 1510
420-110441-22	22-Room 169 Fountain	Drinking Water	09/14/2016 0522	09/19/2016 1510
420-110441-23	23-Left Fountain by Room 13B	Drinking Water	09/14/2016 0523	09/19/2016 1510
420-110441-24	24-Right Fountain by Room 13B	Drinking Water	09/14/2016 0523	09/19/2016 1510
420-110441-25	25-Room 168 Sink	Drinking Water	09/14/2016 0524	09/19/2016 1510
420-110441-26	26-Room 168 Fountain	Drinking Water	09/14/2016 0524	09/19/2016 1510
420-110441-27	27-Room 167 Sink	Drinking Water	09/14/2016 0525	09/19/2016 1510
420-110441-28	28-Room 167 Fountain	Drinking Water	09/14/2016 0525	09/19/2016 1510
420-110441-29	29-Room 110 Sink	Drinking Water	09/14/2016 0526	09/19/2016 1510
420-110441-30	30-Room 110 Fountain	Drinking Water	09/14/2016 0526	09/19/2016 1510
420-110441-31	31-Room 109 Sink	Drinking Water	09/14/2016 0527	09/19/2016 1510
420-110441-32	32-Room 109 Fountain	Drinking Water	09/14/2016 0527	09/19/2016 1510
420-110441-33	33-Teachers Faculty Rom Sink	Drinking Water	09/14/2016 0529	09/19/2016 1510
420-110441-34	34-Mens Teachers Room Sink	Drinking Water	09/14/2016 0529	09/19/2016 1510
420-110441-35	35-Girls Bathroom Sink 1 by Cafe	Drinking Water	09/14/2016 0531	09/19/2016 1510
420-110441-36	36-Girls Bathroom Sink 2 by Cafe	Drinking Water	09/14/2016 0531	09/19/2016 1510
420-110441-37	37-Fountain by Cafeteria	Drinking Water	09/14/2016 0532	09/19/2016 1510
420-110441-38	38-Boys Bathroom Sink 1 by Cafe	Drinking Water	09/14/2016 0533	09/19/2016 1510

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-110441-1
SDG Number: Pine Bush CSD-Pakanasink

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110441-39	39-Boys Bathroom Sink 2 by Cafe	Drinking Water	09/14/2016 0533	09/19/2016 1510
420-110441-40	40-Nurse's Sink	Drinking Water	09/14/2016 0536	09/19/2016 1510
420-110441-41	41-Nurse's Bathroom Sink	Drinking Water	09/14/2016 0537	09/19/2016 1510
420-110441-42	42-Health Suite Bathroom Sink	Drinking Water	09/14/2016 0538	09/19/2016 1510
420-110441-43	43-Mail room bathroom Sink	Drinking Water	09/14/2016 0539	09/19/2016 1510
420-110441-44	44-Principals Office Sink	Drinking Water	09/14/2016 0539	09/19/2016 1510
420-110441-45	45-Room 105 Sink	Drinking Water	09/14/2016 0542	09/19/2016 1510
420-110441-46	46-Room 105 Fountain	Drinking Water	09/14/2016 0542	09/19/2016 1510
420-110441-47	47-Room 106 Sink	Drinking Water	09/14/2016 0543	09/19/2016 1510
420-110441-48	48-Room 106 Fountain	Drinking Water	09/14/2016 0543	09/19/2016 1510
420-110441-49	49-Room 107 Sink	Drinking Water	09/14/2016 0544	09/19/2016 1510
420-110441-50	50-Room 107 Fountain	Drinking Water	09/14/2016 0544	09/19/2016 1510
420-110441-51	51-Room 108 Sink	Drinking Water	09/14/2016 0545	09/19/2016 1510
420-110441-52	52-Room 108 Fountain	Drinking Water	09/14/2016 0545	09/19/2016 1510
420-110441-53	53-Slop Sink by Library	Drinking Water	09/14/2016 0548	09/19/2016 1510
420-110441-54	54-Library Sink	Drinking Water	09/14/2016 0551	09/19/2016 1510
420-110441-55	55-Library Bathroom Sink	Drinking Water	09/14/2016 0552	09/19/2016 1510
420-110441-56	56-Room 101 Sink	Drinking Water	09/14/2016 0553	09/19/2016 1510
420-110441-57	57-Room 101 Fountain	Drinking Water	09/14/2016 0553	09/19/2016 1510
420-110441-58	58-Room 103 Sink	Drinking Water	09/14/2016 0555	09/19/2016 1510
420-110441-59	59-Room 103 Fountain	Drinking Water	09/14/2016 0555	09/19/2016 1510
420-110441-60	60-Fountain by 111A	Drinking Water	09/14/2016 0556	09/19/2016 1510
420-110441-61	61-Room 111A Bathroom Sink	Drinking Water	09/14/2016 0557	09/19/2016 1510
420-110441-62	62-Girls Gym Bathroom Sink 1	Drinking Water	09/14/2016 0601	09/19/2016 1510
420-110441-63	63-Girls Gym Bathroom Sink 2	Drinking Water	09/14/2016 0601	09/19/2016 1510
420-110441-64	64-Boys Gym Bathroom Sink 1	Drinking Water	09/14/2016 0602	09/19/2016 1510
420-110441-65	65-Boys Gym Bathroom Sink 2	Drinking Water	09/14/2016 0602	09/19/2016 1510
420-110441-66	66-Gym Slop Sink	Drinking Water	09/14/2016 0603	09/19/2016 1510
420-110441-67	67-Coaches Bathroom Sink	Drinking Water	09/14/2016 0605	09/19/2016 1510
420-110441-68	68-Gym Courtyard Outside Spigot	Drinking Water	09/14/2016 0607	09/19/2016 1510
420-110441-69	69-Boys Locker Room Sink	Drinking Water	09/14/2016 0610	09/19/2016 1510
420-110441-70	70-Girls Locker Room Sink	Drinking Water	09/14/2016 0610	09/19/2016 1510
420-110441-71	71-Shop Sink by Pool	Drinking Water	09/14/2016 0613	09/19/2016 1510
420-110441-72	72-Pool Fountain Left	Drinking Water	09/14/2016 0614	09/19/2016 1510
420-110441-73	73-Pool Fountain Right	Drinking Water	09/14/2016 0614	09/19/2016 1510
420-110441-74	74-Fountain by Back Music Room	Drinking Water	09/14/2016 0616	09/19/2016 1510
420-110441-75	75-Room 151 Sink	Drinking Water	09/14/2016 0620	09/19/2016 1510
420-110441-76	76-Room 151 Fountain	Drinking Water	09/14/2016 0620	09/19/2016 1510
420-110441-77	77-Room 152 Sink	Drinking Water	09/14/2016 0621	09/19/2016 1510

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-110441-1
SDG Number: Pine Bush CSD-Pakanasink

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110441-78	78-Room 152 Fountain	Drinking Water	09/14/2016 0621	09/19/2016 1510
420-110441-79	79-Room 153 Sink	Drinking Water	09/14/2016 0625	09/19/2016 1510
420-110441-80	80-Room 153 Fountain	Drinking Water	09/14/2016 0625	09/19/2016 1510
420-110441-81	81-Room 154 Sink	Drinking Water	09/14/2016 0627	09/19/2016 1510
420-110441-82	82-Room 154 Fountain	Drinking Water	09/14/2016 0627	09/19/2016 1510
420-110441-83	83-Second Floor Student Bathroom	Drinking Water	09/14/2016 0633	09/19/2016 1510
420-110441-84	84-Room 155 Sink	Drinking Water	09/14/2016 0635	09/19/2016 1510
420-110441-85	85-Room 155 Fountain	Drinking Water	09/14/2016 0635	09/19/2016 1510
420-110441-86	86-Room 156 Sink	Drinking Water	09/14/2016 0637	09/19/2016 1510
420-110441-87	87-Room 156 Fountain	Drinking Water	09/14/2016 0637	09/19/2016 1510
420-110441-88	88-Room 157 Sink	Drinking Water	09/14/2016 0639	09/19/2016 1510
420-110441-89	89-Room 157 Fountain	Drinking Water	09/14/2016 0639	09/19/2016 1510
420-110441-90	90-Room 158 Sink	Drinking Water	09/14/2016 0641	09/19/2016 1510
420-110441-91	91-Room 158 Sink	Drinking Water	09/14/2016 0641	09/19/2016 1510
420-110441-92	92-Second Floor Slop Sink	Drinking Water	09/14/2016 0645	09/19/2016 1510
420-110441-93	93-Room 159 Sink	Drinking Water	09/14/2016 0647	09/19/2016 1510
420-110441-94	94-Room 159 Fountain	Drinking Water	09/14/2016 0647	09/19/2016 1510
420-110441-95	95-Room 160 Sink	Drinking Water	09/14/2016 0649	09/19/2016 1510
420-110441-96	96-Room 160 Fountain	Drinking Water	09/14/2016 0649	09/19/2016 1510
420-110441-97	97-Room 162 Sink	Drinking Water	09/14/2016 0652	09/19/2016 1510
420-110441-98	98-Room 162 Fountain	Drinking Water	09/14/2016 0652	09/19/2016 1510
420-110441-99	99-Room 161 Sink	Drinking Water	09/14/2016 0652	09/19/2016 1510
420-110441-100	100-Room 161 Fountain	Drinking Water	09/14/2016 0654	09/19/2016 1510

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 1-Slop Sink by Loading dock
Lab Sample ID: 420-110441-1

Date Sampled: 09/14/2016 0502
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0153	
Prep Method: 200			Date Prepared:	09/27/2016 1701	
Pb	203 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 2-Kitchen Left Sink
Lab Sample ID: 420-110441-2

Date Sampled: 09/14/2016 0507
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0157	
Prep Method: 200			Date Prepared:	09/27/2016 1701	
Pb	4.54	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 3-Kitchen Right Sink
Lab Sample ID: 420-110441-3

Date Sampled: 09/14/2016 0507
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0200	
Prep Method: 200			Date Prepared:	09/27/2016 1701	
Pb	2.96	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 4-Kitchen Hand Sink
Lab Sample ID: 420-110441-4

Date Sampled: 09/14/2016 0508
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0204	
Prep Method: 200			Date Prepared:	09/27/2016 1701	
Pb	1.91	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 5-Cafeteria Fountain
Lab Sample ID: 420-110441-5

Date Sampled: 09/14/2016 0509
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Prep Method: 200 Pb				Date Analyzed:	09/29/2016	0208
				Date Prepared:	09/27/2016	1701
	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 6- Faculty Room Sink
Lab Sample ID: 420-110441-6

Date Sampled: 09/14/2016 0510
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/29/2016 0211	
Prep Method: 200				Date Prepared:	09/27/2016 1701	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 7- Boys Bathroom Sink by Cafeteria
Lab Sample ID: 420-110441-7

Date Sampled: 09/14/2016 0512
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0215	
Prep Method: 200			Date Prepared:	09/27/2016 1701	
Pb	8.02	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 8-Girls Bathroom Sink by Cafeteria
Lab Sample ID: 420-110441-8

Date Sampled: 09/14/2016 0512
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0225	
Prep Method: 200			Date Prepared:	09/27/2016 1701	
Pb	7.76	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 9-Room 114 Sink
Lab Sample ID: 420-110441-9

Date Sampled: 09/14/2016 0514
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0229	
Prep Method: 200			Date Prepared:	09/27/2016 1701	
Pb	10.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 10-Room 114 Fountain
Lab Sample ID: 420-110441-10

Date Sampled: 09/14/2016 0514
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0233	
Prep Method: 200			Date Prepared:	09/27/2016 1929	
Pb	5.77	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 11-Room 118 Sink
Lab Sample ID: 420-110441-11

Date Sampled: 09/14/2016 0515
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0247	
Prep Method: 200			Date Prepared:	09/27/2016 1929	
Pb	12.5	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 12-Room 118 Fountain
Lab Sample ID: 420-110441-12

Date Sampled: 09/14/2016 0515
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0250	
Prep Method: 200			Date Prepared:	09/27/2016 1929	
Pb	3.88	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 13-Room 116 Sink
Lab Sample ID: 420-110441-13

Date Sampled: 09/14/2016 0516
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0254	
Prep Method: 200			Date Prepared:	09/27/2016 1929	
Pb	24.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 14-Room 116 Fountain
Lab Sample ID: 420-110441-14

Date Sampled: 09/14/2016 0516
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0258	
Prep Method: 200			Date Prepared:	09/27/2016 1929	
Pb	7.56	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 15-Room 172 Sink
Lab Sample ID: 420-110441-15

Date Sampled: 09/14/2016 0519
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0308	
Prep Method: 200			Date Prepared:	09/27/2016 1929	
Pb	1.78	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 16-Room 172 Fountain
Lab Sample ID: 420-110441-16

Date Sampled: 09/14/2016 0519
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016	0312	
Prep Method: 200			Date Prepared:	09/27/2016	1929	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 17-Room 171 Sink
Lab Sample ID: 420-110441-17

Date Sampled: 09/14/2016 0520
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0315	
Prep Method: 200			Date Prepared:	09/27/2016 1929	
Pb	8.93	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 18-Room 171 Fountain
Lab Sample ID: 420-110441-18

Date Sampled: 09/14/2016 0520
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016	0319	
Prep Method: 200			Date Prepared:	09/27/2016	1929	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 19-Room 170 Sink
Lab Sample ID: 420-110441-19

Date Sampled: 09/14/2016 0521
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0323	
Prep Method: 200			Date Prepared:	09/27/2016 1929	
Pb	1.08	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 20-Room 170 Fountain
Lab Sample ID: 420-110441-20

Date Sampled: 09/14/2016 0521
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0326	
Prep Method: 200			Date Prepared:	09/27/2016 1929	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 21-Room 169 Sink
Lab Sample ID: 420-110441-21

Date Sampled: 09/14/2016 0522
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0330	
Prep Method: 200			Date Prepared:	09/27/2016 1929	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 22-Room 169 Fountain
Lab Sample ID: 420-110441-22

Date Sampled: 09/14/2016 0522
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016	0333	
Prep Method: 200			Date Prepared:	09/27/2016	1929	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 23-Left Fountain by Room 13B
Lab Sample ID: 420-110441-23

Date Sampled: 09/14/2016 0523
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/29/2016 0337	
Prep Method: 200				Date Prepared:	09/27/2016 1929	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 24-Right Fountain by Room 13B
Lab Sample ID: 420-110441-24

Date Sampled: 09/14/2016 0523
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/29/2016 0340	
Prep Method: 200				Date Prepared:	09/27/2016 1929	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 25-Room 168 Sink
Lab Sample ID: 420-110441-25

Date Sampled: 09/14/2016 0524
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/29/2016 0351	
Prep Method: 200				Date Prepared:	09/27/2016 1929	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 26-Room 168 Fountain
Lab Sample ID: 420-110441-26

Date Sampled: 09/14/2016 0524
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/29/2016 0355	
Prep Method: 200				Date Prepared:	09/27/2016 1929	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 27-Room 167 Sink
Lab Sample ID: 420-110441-27

Date Sampled: 09/14/2016 0525
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/29/2016 0358	
Prep Method: 200				Date Prepared:	09/27/2016 1929	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 28-Room 167 Fountain
Lab Sample ID: 420-110441-28

Date Sampled: 09/14/2016 0525
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/29/2016 0402	
Prep Method: 200				Date Prepared:	09/27/2016 1929	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 29-Room 110 Sink
Lab Sample ID: 420-110441-29

Date Sampled: 09/14/2016 0526
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0406	
Prep Method: 200			Date Prepared:	09/27/2016 1929	
Pb	11.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 30-Room 110 Fountain
Lab Sample ID: 420-110441-30

Date Sampled: 09/14/2016 0526
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0409	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	2.52	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 31-Room 109 Sink
Lab Sample ID: 420-110441-31

Date Sampled: 09/14/2016 0527
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0424	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	9.92	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 32-Room 109 Fountain
Lab Sample ID: 420-110441-32

Date Sampled: 09/14/2016 0527
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0434	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	2.33	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 33-Teachers Faculty Rom Sink
Lab Sample ID: 420-110441-33

Date Sampled: 09/14/2016 0529
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0438	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	3.67	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 34-Mens Teachers Room Sink
Lab Sample ID: 420-110441-34

Date Sampled: 09/14/2016 0529
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0441	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	4.81	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 35-Girls Bathroom Sink 1 by Cafe
Lab Sample ID: 420-110441-35

Date Sampled: 09/14/2016 0531
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0445	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	1.50	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 36-Girls Bathroom Sink 2 by Cafe
Lab Sample ID: 420-110441-36

Date Sampled: 09/14/2016 0531
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0449	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	3.83	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 37-Fountain by Cafeteria
Lab Sample ID: 420-110441-37

Date Sampled: 09/14/2016 0532
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0452	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	2.87	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 38-Boys Bathroom Sink 1 by Cafe
Lab Sample ID: 420-110441-38

Date Sampled: 09/14/2016 0533
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0456	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	6.14	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 39-Boys Bathroom Sink 2 by Cafe
Lab Sample ID: 420-110441-39

Date Sampled: 09/14/2016 0533
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0459	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	3.02	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 40-Nurse's Sink
Lab Sample ID: 420-110441-40

Date Sampled: 09/14/2016 0536
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0503	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	1.14	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 41-Nurse's Bathroom Sink
Lab Sample ID: 420-110441-41

Date Sampled: 09/14/2016 0537
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0507	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	16.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 42-Health Suite Bathroom Sink
Lab Sample ID: 420-110441-42

Date Sampled: 09/14/2016 0538
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0517	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	2.04	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 43-Mail room bathroom Sink
Lab Sample ID: 420-110441-43

Date Sampled: 09/14/2016 0539
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0521	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	2.58	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 44-Principals Office Sink
Lab Sample ID: 420-110441-44

Date Sampled: 09/14/2016 0539
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0525	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	9.76	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 45-Room 105 Sink
Lab Sample ID: 420-110441-45

Date Sampled: 09/14/2016 0542
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0528	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	15.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 46-Room 105 Fountain
Lab Sample ID: 420-110441-46

Date Sampled: 09/14/2016 0542
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0532	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	2.68	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 47-Room 106 Sink
Lab Sample ID: 420-110441-47

Date Sampled: 09/14/2016 0543
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016	0535	
Prep Method: 200			Date Prepared:	09/27/2016	1845	
Pb	15.5	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 48-Room 106 Fountain
Lab Sample ID: 420-110441-48

Date Sampled: 09/14/2016 0543
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0539	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	2.52	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 49-Room 107 Sink
Lab Sample ID: 420-110441-49

Date Sampled: 09/14/2016 0544
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0543	
Prep Method: 200			Date Prepared:	09/27/2016 1845	
Pb	10.5	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 50-Room 107 Fountain
Lab Sample ID: 420-110441-50

Date Sampled: 09/14/2016 0544
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0546	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	2.76	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 51-Room 108 Sink
Lab Sample ID: 420-110441-51

Date Sampled: 09/14/2016 0545
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/29/2016 0608	
Prep Method: 200				Date Prepared:	09/27/2016 1800	
Pb	19.0	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 52-Room 108 Fountain
Lab Sample ID: 420-110441-52

Date Sampled: 09/14/2016 0545
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/30/2016 1835	
Prep Method: 200			Date Prepared:	09/29/2016 1530	
Pb	5.53	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 53-Slop Sink by Library
Lab Sample ID: 420-110441-53

Date Sampled: 09/14/2016 0548
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0611	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	4.09	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 54-Library Sink
Lab Sample ID: 420-110441-54

Date Sampled: 09/14/2016 0551
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0615	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	1.23	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 55-Library Bathroom Sink
Lab Sample ID: 420-110441-55

Date Sampled: 09/14/2016 0552
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		09/29/2016 0619	
Prep Method: 200		Date Prepared:		09/27/2016 1800	
Pb	6.65	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 56-Room 101 Sink
Lab Sample ID: 420-110441-56

Date Sampled: 09/14/2016 0553
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0622	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	10.9	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 57-Room 101 Fountain
Lab Sample ID: 420-110441-57

Date Sampled: 09/14/2016 0553
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0626	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	1.83	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 58-Room 103 Sink
Lab Sample ID: 420-110441-58

Date Sampled: 09/14/2016 0555
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016	0629	
Prep Method: 200			Date Prepared:	09/27/2016	1800	
Pb	21.7	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 59-Room 103 Fountain
Lab Sample ID: 420-110441-59

Date Sampled: 09/14/2016 0555
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0633	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	11.5	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 60-Fountain by 111A
Lab Sample ID: 420-110441-60

Date Sampled: 09/14/2016 0556
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0644	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	1.52	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 61-Room 111A Bathroom Sink
Lab Sample ID: 420-110441-61

Date Sampled: 09/14/2016 0557
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0647	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	1.43	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 62-Girls Gym Bathroom Sink 1
Lab Sample ID: 420-110441-62

Date Sampled: 09/14/2016 0601
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0651	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	4.08	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 63-Girls Gym Bathroom Sink 2
Lab Sample ID: 420-110441-63

Date Sampled: 09/14/2016 0601
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0655	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	3.74	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 64-Boys Gym Bathroom Sink 1
Lab Sample ID: 420-110441-64

Date Sampled: 09/14/2016 0602
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0658	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	3.08	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 65-Boys Gym Bathroom Sink 2
Lab Sample ID: 420-110441-65

Date Sampled: 09/14/2016 0602
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0702	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	2.87	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 66-Gym Slop Sink
Lab Sample ID: 420-110441-66

Date Sampled: 09/14/2016 0603
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016	0705	
Prep Method: 200			Date Prepared:	09/27/2016	1800	
Pb	28.7	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 67-Coaches Bathroom Sink
Lab Sample ID: 420-110441-67

Date Sampled: 09/14/2016 0605
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0709	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	6.40	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 68-Gym Courtyard Outside Spigot
Lab Sample ID: 420-110441-68

Date Sampled: 09/14/2016 0607
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0713	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	9.57	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 69-Boys Locker Room Sink
Lab Sample ID: 420-110441-69

Date Sampled: 09/14/2016 0610
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0716	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	6.42	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 70-Girls Locker Room Sink
Lab Sample ID: 420-110441-70

Date Sampled: 09/14/2016 0610
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 0727	
Prep Method: 200			Date Prepared:	09/27/2016 1800	
Pb	9.75	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 71-Shop Sink by Pool
Lab Sample ID: 420-110441-71

Date Sampled: 09/14/2016 0613
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1012	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	9.41	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 72-Pool Fountain Left
Lab Sample ID: 420-110441-72

Date Sampled: 09/14/2016 0614
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016	1026	
Prep Method: 200			Date Prepared:	09/28/2016	1734	
Pb	36.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 73-Pool Fountain Right
Lab Sample ID: 420-110441-73

Date Sampled: 09/14/2016 0614
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1030	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	14.5	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 74-Fountain by Back Music Room
Lab Sample ID: 420-110441-74

Date Sampled: 09/14/2016 0616
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/29/2016 1033	
Prep Method: 200				Date Prepared:	09/28/2016 1734	
Pb	17.2	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 75-Room 151 Sink
Lab Sample ID: 420-110441-75

Date Sampled: 09/14/2016 0620
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/29/2016 1037	
Prep Method: 200				Date Prepared:	09/28/2016 1734	
Pb	15.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 76-Room 151 Fountain
Lab Sample ID: 420-110441-76

Date Sampled: 09/14/2016 0620
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016	1040	
Prep Method: 200			Date Prepared:	09/28/2016	1734	
Pb	21.0	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 77-Room 152 Sink
Lab Sample ID: 420-110441-77

Date Sampled: 09/14/2016 0621
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016	1051	
Prep Method: 200			Date Prepared:	09/28/2016	1734	
Pb	15.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 78-Room 152 Fountain
Lab Sample ID: 420-110441-78

Date Sampled: 09/14/2016 0621
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1054	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	6.74	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 79-Room 153 Sink
Lab Sample ID: 420-110441-79

Date Sampled: 09/14/2016 0625
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	09/29/2016 1058	
Prep Method: 200				Date Prepared:	09/28/2016 1734	
Pb	17.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 80-Room 153 Fountain
Lab Sample ID: 420-110441-80

Date Sampled: 09/14/2016 0625
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1101	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	13.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 81-Room 154 Sink
Lab Sample ID: 420-110441-81

Date Sampled: 09/14/2016 0627
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1105	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	3.13	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 82-Room 154 Fountain
Lab Sample ID: 420-110441-82

Date Sampled: 09/14/2016 0627
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1108	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	5.08	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 83-Second Floor Student Bathroom
Lab Sample ID: 420-110441-83

Date Sampled: 09/14/2016 0633
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1112	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	2.33	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 84-Room 155 Sink
Lab Sample ID: 420-110441-84

Date Sampled: 09/14/2016 0635
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1115	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	10.9	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 85-Room 155 Fountain
Lab Sample ID: 420-110441-85

Date Sampled: 09/14/2016 0635
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1119	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	2.58	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 86-Room 156 Sink
Lab Sample ID: 420-110441-86

Date Sampled: 09/14/2016 0637
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1122	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	10.7	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 87-Room 156 Fountain
Lab Sample ID: 420-110441-87

Date Sampled: 09/14/2016 0637
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1133	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	2.26	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 88-Room 157 Sink
Lab Sample ID: 420-110441-88

Date Sampled: 09/14/2016 0639
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1136	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	8.99	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 89-Room 157 Fountain
Lab Sample ID: 420-110441-89

Date Sampled: 09/14/2016 0639
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1140	
Prep Method: 200			Date Prepared:	09/28/2016 1734	
Pb	3.07	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 90-Room 158 Sink
Lab Sample ID: 420-110441-90

Date Sampled: 09/14/2016 0641
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1143	
Prep Method: 200			Date Prepared:	09/28/2016 1802	
Pb	14.4	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 91-Room 158 Sink
Lab Sample ID: 420-110441-91

Date Sampled: 09/14/2016 0641
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1157	
Prep Method: 200			Date Prepared:	09/28/2016 1802	
Pb	2.51	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 92-Second Floor Slop Sink
Lab Sample ID: 420-110441-92

Date Sampled: 09/14/2016 0645
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1201	
Prep Method: 200			Date Prepared:	09/28/2016 1802	
Pb	13.9	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 93-Room 159 Sink
Lab Sample ID: 420-110441-93

Date Sampled: 09/14/2016 0647
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1204	
Prep Method: 200			Date Prepared:	09/28/2016 1802	
Pb	11.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 94-Room 159 Fountain
Lab Sample ID: 420-110441-94

Date Sampled: 09/14/2016 0647
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1215	
Prep Method: 200			Date Prepared:	09/28/2016 1802	
Pb	3.04	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 95-Room 160 Sink
Lab Sample ID: 420-110441-95

Date Sampled: 09/14/2016 0649
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1218	
Prep Method: 200			Date Prepared:	09/28/2016 1802	
Pb	14.4	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 96-Room 160 Fountain
Lab Sample ID: 420-110441-96

Date Sampled: 09/14/2016 0649
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1222	
Prep Method: 200			Date Prepared:	09/28/2016 1802	
Pb	3.42	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 97-Room 162 Sink
Lab Sample ID: 420-110441-97

Date Sampled: 09/14/2016 0652
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1225	
Prep Method: 200			Date Prepared:	09/28/2016 1802	
Pb	14.2	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 98-Room 162 Fountain
Lab Sample ID: 420-110441-98

Date Sampled: 09/14/2016 0652
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1229	
Prep Method: 200			Date Prepared:	09/28/2016 1802	
Pb	3.04	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 99-Room 161 Sink
Lab Sample ID: 420-110441-99

Date Sampled: 09/14/2016 0652
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1232	
Prep Method: 200			Date Prepared:	09/28/2016 1802	
Pb	11.7	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-110441-1
Sdg Number: Pine Bush CSD-Pakanasink

Client Sample ID: 100-Room 161 Fountain
Lab Sample ID: 420-110441-100

Date Sampled: 09/14/2016 0654
Date Received: 09/19/2016 1510
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	09/29/2016 1236	
Prep Method: 200			Date Prepared:	09/28/2016 1802	
Pb	5.30	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:
Sdg Number: Pine Bush CSD-Pakanasink

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Pine Bush CSD-Pakanasink

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalien Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture) , Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Pine Bush CSD-Pakanasink

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.



REPORT# (Lab Use Only)

Laboratories, Inc.

Lab Name **EnviroTest Laboratories**
Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

PROJECT REFERENCE		PROJECT NO.	PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES										PAGE 1 of 8																
ENVIRONMENTAL PROJECT MANAGER		P.O. NUMBER	TOWN	CLIENT PHONE	CLIENT FAX	D (Drinking Water) or V (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	Total # of Containers						40ml Vials HCl	1 Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	TURNAROUND TIME									
CLIENT (SITE) PM	CLIENT NAME	CLIENT PHONE	CLIENT FAX	CLIENT (SITE) PM	CLIENT NAME				CLIENT PHONE	CLIENT FAX	COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE											COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE
Pine Bush CSD - Pakanasink																																	
Debra Bayer																																	
Jack DeGraw																																	
Orange-Ulster BOCES																																	
53 Gibson Road, Goshen, NY 10924																																	
COMPANY CONTRACTING THIS WORK (if applicable):																																	
SAMPLE IDENTIFICATION		DATE		TIME		COMPOSITE (C) OR GRAB (G) INDICATE		SOLID OR SEMISOLID		OTHER Specify		Total # of Containers		40ml Vials HCl		1 Liter Amber HCl		250ml Plastic Nitric Acid		250ml Plastic Sulfuric Acid		Liter Plastic		250ml Plastic		Terra Core		Other		Other		TURNAROUND TIME	
9/14/2016		5:02		1 - Slop Sink by Loading dock		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:07		2 - Kitchen Left Sink		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:07		3 - Kitchen Right Sink		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:08		4 Kitchen Hand Sink		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:09		5 - Cafeteria Fountain		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:10		6 - Faculty Room Sink		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:12		7 - Boys Bathroom Sink by Cafeteria		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:12		8 - Girls Bathroom Sink by Cafeteria		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:14		9 - Room 114 Sink		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:14		10 - Room 114 Fountain		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:15		11 - Room 118 Sink		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:15		12 - Room 118 Fountain		G		D				1		1		1		1		1		1		1		1		1		1		Lead (DW 200.8)	
9/14/2016		5:16																															

12#3

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	Cooler Temp(C):

Pres of nitric acid at lab 9/19/16 @ 1545. Nitric acid man'f by
Fisher Chemical, lot # 161446. QZ 9/19/16



REPORT# (Lab Use Only)

110441

Lab Name **EnviroTest Laboratories**
Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

PROJECT REFERENCE	PROJECT NO.	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES	REMARKS
Pine Bush CSD - Pakanasink		TOWN			
ENVIREST PROJECT MANAGER	P.O. NUMBER				
Debra Bayer	CLIENT PHONE	CLIENT FAX			
CLIENT (SITE) PM	845-781-4887				
CLIENT NAME	Orange-Ulster BOCES				
CLIENT ADDRESS	53 Gibson Road, Goshen, NY 10924				
COMPANY CONTRACTING THIS WORK (if applicable):					
SAMPLE IDENTIFICATION					
SAMPLE	DATE	TIME			
9/14/2016	5:16	14 - Room 116 Fountain	G	D	Lead (DW 200.8)
9/14/2016	5:19	15 - Room 172 Sink	G	D	Lead (DW 200.8)
9/14/2016	5:19	16 - Room 172 Fountain	G	D	Lead (DW 200.8)
9/14/2016	5:20	17 - Room 171 Sink	G	D	Lead (DW 200.8)
9/14/2016	5:20	18 - Room 171 Fountain	G	D	Lead (DW 200.8)
9/14/2016	5:21	19 - Room 170 Sink	G	D	Lead (DW 200.8)
9/14/2016	5:21	20 - Room 170 Fountain	G	D	Lead (DW 200.8)
9/14/2016	5:22	21 - Room 169 Sink	G	D	Lead (DW 200.8)
9/14/2016	5:22	22 - Room 169 Fountain	G	D	Lead (DW 200.8)
9/14/2016	5:23	23 - Left Fountain by Room 13B	G	D	Lead (DW 200.8)
9/14/2016	5:23	24 - Right Fountain by Room 13B	G	D	Lead (DW 200.8)
9/14/2016	5:24	25 - Room 168 Sink	G	D	Lead (DW 200.8)
9/14/2016	5:24	26 - Room 168 Fountain	G	D	Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE)			DATE		
COMPANY			TIME		
SAMPLED BY: (SIGNATURE)			DATE		
COMPANY			TIME		
RELINQUISHED BY: (SIGNATURE)			DATE		
COMPANY			TIME		

LABORATORY REMARKS: JOE (✓) NO pH ____ Cl₂ ____ Reviewed by ____

* Pres w/ nitric acid at lab 9/19/16 @ 1545. Nitric acid man'f
by Fisher Chemical, lot # 161446. Q.E. 9/19/16



CHAIN OF CUSTODY


Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

110441

PROJECT REFERENCE Pine Bush CSD - Pakanasink		PROJECT NO.	PROJECT LOCATION		MATRIX TYPE		REQUIRED ANALYSES						PAGE 3 of 8
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		OTHER SPECIFY		Other						1
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX		AQUEOUS (WATER) D (Drinking Water) or W (Waste Water) Indicate		250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid Liter Plastic 250ml Plastic Nitric Acid Liter Amber HCl 40ml Vials HCl						TURNAROUND TIME
CLIENT NAME Orange-Ulster BOCES		christy.fischer@outboxes.org		COMPOSITE (C) OR GRAB (G) INDICATE		NUMBER OF CONTAINERS SUBMITTED						NORMAL	
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924		COMPANY CONTRACTING THIS WORK (if applicable)		DATE		RECEIVED BY: (SIGNATURE)						QUICK	
SAMPLE IDENTIFICATION		DATE		TIME		RECEIVED BY: (SIGNATURE)						VERBAL	
9/14/2016		5:25		27 - Room 167 Sink		RECEIVED BY: (SIGNATURE)						#OF COOLERS	
9/14/2016		5:25		28 - Room 167 Fountain		RECEIVED BY: (SIGNATURE)						REMARKS	
9/14/2016		5:26		29 Room 110 Sink		RECEIVED BY: (SIGNATURE)						Lead (DW 200.8)	
9/14/2016		5:26		30 - Room 110 Fountain		RECEIVED BY: (SIGNATURE)						Lead (DW 200.8)	
9/14/2016		5:27		31 - Room 109 Sink		RECEIVED BY: (SIGNATURE)						Lead (DW 200.8)	
9/14/2016		5:27		32 - Room 109 Fountain		RECEIVED BY: (SIGNATURE)						Lead (DW 200.8)	
9/14/2016		5:29		33 - Teachers Faculty Room Sink		RECEIVED BY: (SIGNATURE)						Lead (DW 200.8)	
9/14/2016		5:29		34 - Mens Teachers room Sink		RECEIVED BY: (SIGNATURE)						Lead (DW 200.8)	
9/14/2016		5:31		35 - Girls Bathroom Sink 1 by Café		RECEIVED BY: (SIGNATURE)						Lead (DW 200.8)	
9/14/2016		5:31		36 - Girls Bathroom Sink 2 by Café		RECEIVED BY: (SIGNATURE)						Lead (DW 200.8)	
9/14/2016		5:32		37 - Fountain by Cafeteria		RECEIVED BY: (SIGNATURE)						Lead (DW 200.8)	
9/14/2016		5:33		38 - Boys Bathroom Sink 1 by Café		RECEIVED BY: (SIGNATURE)						Lead (DW 200.8)	
9/14/2016		5:33		39 - Boys Bathroom Sink 2 by Café		RECEIVED BY: (SIGNATURE)						Lead (DW 200.8)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)						COMP DATE	
SAMPLED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)						TIME	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)						COMP DATE	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)						COMP DATE	
RECEIVED FOR ANALYSIS BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)						COMP DATE	
RECEIVED FOR ANALYSIS BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)						COMP DATE	

* Pres w/ nitric acid at lab 9/19/16 @ 1545. Nitric acid man'f by Fisher Chemical, lot #161446. AE 9/19/16



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

110441

Lab Name
Address & Phone
EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Pine Bush OSD - Pakanasink		PROJECT NO.	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES						PAGE 1 of 48
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	☐ SOLID OR SEMISOLID ☐ D (Drinking Water) or V (Waste Water) Indicate ☐ AQUEOUS (WATER) ☐ COMPOSITE (C) OR GRAB (G) INDICATE	40ml Amber HCl	250ml Plastic Sulfuric Acid	250ml Plastic	Terra Core	Other	TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX		Liter Plastic	Other					
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubores.org									
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924											
COMPANY CONTRACTING THIS WORK (if applicable):											
SAMPLE IDENTIFICATION		DATE		TIME	NUMBER OF CONTAINERS SUBMITTED						
9/14/2016		5:36			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:37			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:38			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:39			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:39			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:42			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:42			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:43			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:43			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:44			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:44			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:45			1	1	1	1	1	Lead (DW 200.8)	
9/14/2016		5:45			1	1	1	1	1	Lead (DW 200.8)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME	RECEIVED BY: (SIGNATURE)						
SAMPLED BY: (SIGNATURE)		DATE		TIME	RECEIVED BY: (SIGNATURE)						
RELINQUISHED BY: (SIGNATURE)		DATE		TIME	RECEIVED BY: (SIGNATURE)						
RELINQUISHED BY: (SIGNATURE)		DATE		TIME	RECEIVED BY: (SIGNATURE)						

RECEIVED FOR ANALYSIS BY: (SIGNATURE)		DATE	TIME	GLISTODY INTACT	COOLER TEMP (C)
9/14/2016		9/14/16	5:36	YES	21.9
LABORATORY REMARKS: ICE (Y/N) pH CL2		Revised by			
* Pres. w/ nitric acid at lab 9/19/16 @ 1545. Nitric acid man'f by Fisher Chemical, lot #161446. OE 9/19/16					

CHAIN OF CUSTODY

REPORT# (Lab Use Only)

110441

Lab Name EnviroTest Laboratories
Address & Phone 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE		PROJECT NO.	PROJECT LOCATION		MATRIX TYPE	REQUIRED ANALYSES								PAGE
Pine Bush CSD - Pakanasink			TOWN		OTHER Specify	Total # of Containers	40ml Vials HCl	Liter Amber HCl	* 250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	TURNAROUND TIME
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER												
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX											NORMAL
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org												QUICK
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924														VERBAL
COMPANY CONTRACTING THIS WORK (If applicable)														#OF COOLERS
SAMPLE IDENTIFICATION		DATE		TIME	SAMPLE	NUMBER OF CONTAINERS SUBMITTED						REMARKS		
9/14/2016	5:48	53 - Slop Sink by Library	G	D		1	1							Lead (DW 200.8)
9/14/2016	5:51	54 - Library Sink	G	D		1	1							Lead (DW 200.8)
9/14/2016	5:52	55 - Library Bathroom Sink	G	D		1	1							Lead (DW 200.8)
9/14/2016	5:53	56 - Room 101 Sink	G	D		1	1							Lead (DW 200.8)
9/14/2016	5:53	57 - Room 101 Fountain	G	D		1	1							Lead (DW 200.8)
9/14/2016	5:55	58 - Room Room 103 Sink	G	D		1	1							Lead (DW 200.8)
9/14/2016	5:55	59 - Room Room 103 Fountain	G	D		1	1							Lead (DW 200.8)
9/14/2016	5:56	60 - Fountain by 111A	G	D		1	1							Lead (DW 200.8)
9/14/2016	5:57	61 Room 111A Bathroom Sink	G	D		1	1							Lead (DW 200.8)
9/14/2016	6:01	62 - Girls Gym Bathroom Sink 1	G	D		1	1							Lead (DW 200.8)
9/14/2016	6:01	63 - Girls Gym Bathroom Sink 2	G	D		1	1							Lead (DW 200.8)
9/14/2016	6:02	64 - Boys Gym Bathroom Sink 1	G	D		1	1							Lead (DW 200.8)
9/14/2016	6:02	65 - Boys Gym Bathroom Sink 2	G	D		1	1							Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) _____ DATE _____ COMPANY Orange-Ulster BOCES

SAMPLED BY: (SIGNATURE) *[Signature]* DATE 9/17/16 COMPANY oubooces

RELINQUISHED BY: (SIGNATURE) *[Signature]* DATE 9/16/16 COMPANY oubooces

LABORATORY REMARKS: ICE (Y) N pH 7 CL2 Received by

Cooler Temp(C):..

CUSTODY INTACT

TIME	C
------	---

DATE / /

100

NATURE)

BY: (sig)

PERATOR

FOR LABS

~~RECEIVED~~

Pres w/nitric acid at lab 9/19/16 @ 1545. Nitric acid man'f
by Fisher Chemical, lot #161446. Q&E 9/19/16



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

110441

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Pine Bush CSD - Pakanasink		PROJECT NO.	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES					PAGE 1 of 8
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	☐ AQUEOUS (WATER) ☐ DRINKING WATER or W (Waste Water) Indicate ☐ SOLID OR SEMISOLID OTHER Specify	40ml Amber HCl	250ml Plastic Sulfuric Acid	1 Liter Plastic	250ml Plastic	Terra Core	Other
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX		Liter Amber HCl	250ml Plastic Nitric Acid	1 Liter Plastic	250ml Plastic	Terra Core	Other
CLIENT NAME Orange-Ulster BOCES		christy.fischer.oubooces.org			Total # of Containers					
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924					NUMBER OF CONTAINERS SUBMITTED					
COMPANY CONTRACTING THIS WORK (if applicable)					# OF COOLERS					
SAMPLE IDENTIFICATION		DATE		TIME	REMARKS					
9/14/2016		6:03			Lead (DW 200.8)					
9/14/2016		6:05			Lead (DW 200.8)					
9/14/2016		6:07			Lead (DW 200.8)					
9/14/2016		6:10			Lead (DW 200.8)					
9/14/2016		6:10			Lead (DW 200.8)					
9/14/2016		6:13			Lead (DW 200.8)					
9/14/2016		6:14			Lead (DW 200.8)					
9/14/2016		6:14			Lead (DW 200.8)					
9/14/2016		6:16			Lead (DW 200.8)					
9/14/2016		6:20			Lead (DW 200.8)					
9/14/2016		6:20			Lead (DW 200.8)					
9/14/2016		6:21			Lead (DW 200.8)					
9/14/2016		6:21			Lead (DW 200.8)					

RECEIVED FOR LABORATORY BY: (SIGNATURE)		DATE	TIME	CUSTODY INTACT	COOLER TEMP (C):
<i>[Signature]</i>		9/14/16	2:03	YES	21.9
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	CUSTODY INTACT	COOLER TEMP (C):
<i>[Signature]</i>		9/19/16	3:10	YES	21.9

Res w/ nitric acid at lab 9/19/16 @ 1545. Nitric acid manifest by Fisher Chemical, lot #161446. QE 9/19/16

As per bottle label. QE 9-19-16

As per bottle label. QE 9-19-16



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

110441

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Pine Bush CSD - Pakanasink		PROJECT NO.	PROJECT LOCATION		MATRIX TYPE	REQUIRED ANALYSES		PAGE 7 of 8	
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		OTHER SPECIFY	Other		TURNAROUND TIME	
CLIENT (SITE) PM Jack DeGraw		CLIENT PHONE 845-781-4887	CLIENT FAX			Other			
CLIENT NAME Orange-Ulster BOCES		christy.fischer@oubooces.org		Other					
CLIENT ADDRESS 53 Gibson Road, Goshen, NY 10924		COMPANY CONTRACTING THIS WORK (if applicable)		COMPOSITE (C) OR GRAB (G) INVOICED		250ml Plastic Bottle Acid		# OF COOLERS	
SAMPLE IDENTIFICATION		DATE		TIME		250ml Plastic Bottle Acid			
DATE		TIME		TIME		250ml Plastic Bottle Acid			
9/14/2016		6:25		79 Room 153 Sink		1		Lead (DW 200.8)	
9/14/2016		6:25		80 Room 153 Fountain		1		Lead (DW 200.8)	
9/14/2016		6:27		81 Room 154 Sink		1		Lead (DW 200.8)	
9/14/2016		6:27		82 Room 154 Fountain		1		Lead (DW 200.8)	
9/14/2016		6:33		83 Second Floor Student Bathroom		1		Lead (DW 200.8)	
9/14/2016		6:35		84 Room 155 Sink		1		Lead (DW 200.8)	
9/14/2016		6:35		85 Room 155 Fountain		1		Lead (DW 200.8)	
9/14/2016		6:37		86 Room 156 Sink		1		Lead (DW 200.8)	
9/14/2016		6:37		87 Room 156 Fountain		1		Lead (DW 200.8)	
9/14/2016		6:39		88 Room 157 Sink		1		Lead (DW 200.8)	
9/14/2016		6:39		89 Room 157 Fountain		1		Lead (DW 200.8)	
9/14/2016		6:41		90 Room 158 Sink		1		Lead (DW 200.8)	
9/14/2016		6:41		91 Room 158 Fountain		1		Lead (DW 200.8)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		COMPADATE	
SAMPLED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		COMPADATE	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		COMPADATE	

RECEIVED FOR LABORATORY BY: (SIGNATURE) DATE 9/14/16 TIME 1510 CUSTODY INTACT YES NO
LABORATORY REMARKS: ICE (Y/N) pH CL2 Reviewed by
* Pres w/ nitric acid at lab 9/19/16 @ 1545. Nitric acid man'f
by Fisher Chemical, lot # 161446. OE 9-19-16



REPORT# (Lab Use Only)

Laboratories, Inc.

Lab Name **EnviroTest Laboratories**
Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

[illegible]

* Pres w/ nitric acid at lab 9/19/16 @ 1545. Nitric acid man'f by Fisher Chemical, lot #161446. QX 9-19-16

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-110441-1

SDG Number: Pine Bush CSD-Pakanasink

Login Number: 110441

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is recorded.	True	21.9 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	Preserved with nitric acid at lab 9/19/16 @1545. AE 9/19/16
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	