315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890


July 2, 2024

Maureen Doherty
NB-Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Project Location: Circleville MS
Project Number: Pine Bush CSD-Circleville MS
Laboratory Work Order Number: 24F1861

Enclosed are results of analyses for samples received by the laboratory on June 13, 2024. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Project Manager

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924
ATTN: Maureen Doherty

REPORT DATE: 7/2/2024

PURCHASE ORDER NUMBER:

PROJECT NUMBER: Pine Bush CSD-Circleville MS

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24F1861

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: Circleville MS

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
O/S B139CU/BF	24F1861-01	Drinking Water		EPA 200.8 Rev 5.4	
O/S B139CU/DF	24F1861-02	Drinking Water		EPA 200.8 Rev 5.4	
Main Office KS	24F1861-03	Drinking Water		EPA 200.8 Rev 5.4 (1994)	
O/S A44 BF	24F1861-04	Drinking Water		EPA 200.8 Rev 5.4	
Cafe Right CU/DF	24F1861-05	Drinking Water		EPA 200.8 Rev 5.4	
Cafe Left CU/BF	24F1861-06	Drinking Water		EPA 200.8 Rev 5.4	
Cafe Left CU/DF	24F1861-07	Drinking Water		EPA 200.8 Rev 5.4	
Kitchen KS Prep Office	24F1861-08	Drinking Water		EPA 200.8 Rev 5.4	
Kitchen KS O/S Kitchen	24F1861-09	Drinking Water		EPA 200.8 Rev 5.4	
Kitchen KF	24F1861-10	Drinking Water		EPA 200.8 Rev 5.4	
A75 Girls Locker Rm CU/BF	24F1861-11	Drinking Water		EPA 200.8 Rev 5.4	
A75 Girls Locker Rm CU/DF Left	24F1861-12	Drinking Water		EPA 200.8 Rev 5.4	
A75 Girls Locker Rm CU/DF Right	24F1861-13	Drinking Water		EPA 200.8 Rev 5.4	
A85 Boys Locker Rm CU/BF	24F1861-14	Drinking Water		EPA 200.8 Rev 5.4	
A85 Boys Locker Rm CU/DF	24F1861-15	Drinking Water		EPA 200.8 Rev 5.4	
52A Home ECKS #1 L To R	24F1861-16	Drinking Water		EPA 200.8 Rev 5.4	
52A Home ECKS #2 L To R	24F1861-17	Drinking Water		EPA 200.8 Rev 5.4	
52A Home ECKS #3 L To R	24F1861-18	Drinking Water		EPA 200.8 Rev 5.4	
52A Home ECKS #4 L To R	24F1861-19	Drinking Water		EPA 200.8 Rev 5.4	
52A Home ECKS #5 L To R	24F1861-20	Drinking Water		EPA 200.8 Rev 5.4	
O/S B219 CU/BF	24F1861-21	Drinking Water		EPA 200.8 Rev 5.4	
O/S B219 CU/DF	24F1861-22	Drinking Water		EPA 200.8 Rev 5.4	
O/S B205 CU/BF	24F1861-23	Drinking Water		EPA 200.8 Rev 5.4	
O/S B205 CU/DF	24F1861-24	Drinking Water		EPA 200.8 Rev 5.4	
O/S B144 CU/BF	24F1861-25	Drinking Water		EPA 200.8 Rev 5.4	
O/S B144 CU/DF	24F1861-26	Drinking Water		EPA 200.8 Rev 5.4	
O/S A36 BF	24F1861-27	Drinking Water		EPA 200.8 Rev 5.4	
O/S A61 BF	24F1861-28	Drinking Water		EPA 200.8 Rev 5.4	
Faculty/ 13131 KS	24F1861-29	Drinking Water		EPA 200.8 Rev 5.4	
B 141 Kitchen Sink	24F1861-30	Drinking Water		EPA 200.8 Rev 5.4 (1994)	
Nurses Sink	24F1861-31	Drinking Water		EPA 200.8 Rev 5.4	
Cafe Right CU/BF	24F1861-32	Drinking Water		EPA 200.8 Rev 5.4	
O/S B 219 BF	24F1861-33	Drinking Water		EPA 200.8 Rev 5.4	

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

EPA 200.8 Rev 5.4 (1994)

Qualifications:

Z-01


#

Analyte & Samples(s) Qualified:

Lead

24F1861-03[Main Office KS], 24F1861-30[B 141 Kitchen Sink]

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.
I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Felicia Morgan-Nichols
Project Manager

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S B139CU/BF | Sampled: 6/11/2024 03:30

Sample ID: 24F1861-01

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/24/24 21:17	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S B139CU/DF | Sampled: 6/11/2024 03:30

Sample ID: 24F1861-02

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/24/24 21:34	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: Main Office KS | Sampled: 6/11/2024 03:32

Sample ID: 24F1861-03

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	68		1.5	µg/L	1	Z-01	EPA 200.8 Rev 5.4 (1994)	6/25/24	7/1/24 13:20	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S A44 BF | Sampled: 6/11/2024 03:33

Sample ID: 24F1861-04

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/24/24 21:37	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: Cafe Right CU/DF | Sampled: 6/11/2024 03:36

Sample ID: 24F1861-05

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/24/24 21:39	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: Cafe Left CU/BF | Sampled: 6/11/2024 03:37

Sample ID: 24F1861-06

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/24/24 21:42	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: Cafe Left CU/DF | Sampled: 6/11/2024 03:37

Sample ID: 24F1861-07

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/24/24 21:45	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: Kitchen KS Prep Office | Sampled: 6/11/2024 03:40

Sample ID: 24F1861-08

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/24/24 21:48	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: Kitchen KS O/S Kitchen | Sampled: 6/11/2024 03:40

Sample ID: 24F1861-09

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	5.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/24/24 21:50	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: Kitchen KF | Sampled: 6/11/2024 03:40

Sample ID: 24F1861-10

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/24/24 21:53	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: A75 Girls Locker Rm CU/BF | Sampled: 6/11/2024 03:45

Sample ID: 24F1861-11

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/24/24 21:56	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: A75 Girls Locker Rm CU/DF Left | Sampled: 6/11/2024 03:46

Sample ID: 24F1861-12

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 9:30	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: A75 Girls Locker Rm CU/DF Right | Sampled: 6/11/2024 03:47

Sample ID: 24F1861-13

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 9:36	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: A85 Boys Locker Rm CU/BF | Sampled: 6/11/2024 03:43

Sample ID: 24F1861-14

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 9:39	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: A85 Boys Locker Rm CU/DF | Sampled: 6/11/2024 03:43

Sample ID: 24F1861-15

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 9:42	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: 52A Home ECKS #1 L To R | Sampled: 6/11/2024 03:53

Sample ID: 24F1861-16

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	5.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 9:44	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: 52A Home ECKS #2 L To R | Sampled: 6/11/2024 03:53

Sample ID: 24F1861-17

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	3.9	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 9:47	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: 52A Home ECKS #3 L To R | Sampled: 6/11/2024 03:53

Sample ID: 24F1861-18

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	4.8	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 9:50	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: 52A Home ECKS #4 L To R | Sampled: 6/11/2024 03:53

Sample ID: 24F1861-19

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	14	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 9:53	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: 52A Home ECKS #5 L To R | Sampled: 6/11/2024 03:53

Sample ID: 24F1861-20

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	4.9	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:01	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S B219 CU/BF | Sampled: 6/11/2024 04:08

Sample ID: 24F1861-21

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:04	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S B219 CU/DF | Sampled: 6/11/2024 04:08

Sample ID: 24F1861-22

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:07	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S B205 CU/BF | Sampled: 6/11/2024 04:06

Sample ID: 24F1861-23

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:18	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S B205 CU/DF | Sampled: 6/11/2024 04:06

Sample ID: 24F1861-24

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:20	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S B144 CU/BF | Sampled: 6/11/2024 03:58

Sample ID: 24F1861-25

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:23	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S B144 CU/DF | Sampled: 6/11/2024 03:58

Sample ID: 24F1861-26

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:26	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S A36 BF | Sampled: 6/11/2024 03:48

Sample ID: 24F1861-27

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:34	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S A61 BF | Sampled: 6/11/2024 03:55

Sample ID: 24F1861-28

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:37	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: Faculty/ 13131 KS | Sampled: 6/11/2024 03:57

Sample ID: 24F1861-29

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:40	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: B 141 Kitchen Sink | Sampled: 6/11/2024 04:01

Sample ID: 24F1861-30

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	25		1.5	µg/L	1	Z-01	EPA 200.8 Rev 5.4 (1994)	6/25/24	7/1/24 13:22	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: Nurses Sink | Sampled: 6/11/2024 04:03

Sample ID: 24F1861-31

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	2.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:43	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: Cafe Right CU/BF | Sampled: 6/12/2024 06:34

Sample ID: 24F1861-32

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:45	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Circleville MS | Sample Description: | Work Order: 24F1861

Date Received: 6/13/2024

Field Sample #: O/S B 219 BF | Sampled: 6/12/2024 06:36

Sample ID: 24F1861-33

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/21/24	6/25/24 10:48	JC

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level

Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.

No results have been blank subtracted unless specified in the case narrative section.

Z-01	#

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 Rev 5.4 in Drinking Water	
Lead	NB-CT,NB-NJ,NB-NY
EPA 200.8 Rev 5.4 (1994) in Water	
Lead	NB-CT,NB-NJ,NB-NY

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2024
NB-NY	New York State Department of Health	10142 NELAP	03/31/2025

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

24F1861-1

Scan QR Code for instructions

Company Name: Orange-Ulster BOCES	Contact/Report To: Maureen Doherty
Street Address: 53 Gibson Road, Goshen, NY 10924	Phone #: 845-781-4887
	E-Mail: Maureen.Doherty@ouboces.org
	Cc E-Mail: Halina.redner@ouboces.org
Customer Project #:	Invoice to: Halina Redner
Project Name: Pine Bush CSD - Circleville MS	Invoice E-mail: halina.redner@ouboces.org
Site Collection Info/Facility ID (as applicable):	Purchase Order # (if applicable): A24-00300
	Quote #:
Time Zone Collected: [ ] AK [X] PT [ ] MT [ ] CT [X] ET	County / State origin of sample(s): Orange County / New York
Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other	Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No
	Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other _____ **Date Results Requested:**
	DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): [ ] Yes [ ] No Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

Specify Container Size **: 3

Identify Container Preservative Type***: 2

Analysis Requested: Lead

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: / AcctNum / Client ID: / Table #: / Profile / Template: / Prelog / Bottle Ord. ID:

Preservation non-conformance identified for sample.

	Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Lead	Sample Comment
1	O/S B139 CU/BF	DW	G			6/11/24	3:30	1			X	
2	O/S B139 CU/DF	DW	G				3:30	1			X	
3	Main office KS	DW	G				3:32	1			X	
4	O/S A44 BF	DW	G				3:33	1			X	
5	Cafe Right CU/DF	DW	G				3:36	1			X	
6	Cafe Left CU/BF	DW	G				3:37	1			X	
7	Cafe Left CU/DF	DW	G				3:37	1			X	
8	Kitchen KS Prep	DW	G				3:40	1			X	
9	Kitchen KS O/S Kitchen office	DW	G				3:40	1			X	
10	Kitchen KF	DW	G				3:40	1			X	

24F1861

Additional Instructions from Pace® :

Collected By: Printed Name: MiKayla Higgins Signature: MiKayla Higgins

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp. (°C):	[ ] On Ice
				20.0	NO

Relinquished by/Company: (Signature) MiKayla Higgins	Date/Time: 6/13/24; 1258	Received by/Company: (Signature)	Date/Time: 6/13/24 1258	Tracking Number:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Delivered by: [ ] In-Person [ ] Courier [ ] FedEx [ ] UPS [ ] Other
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Page: 1 of 4

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

24F1861-2

Scan QR Code for instructions

Company Name: Orange-Ulster BOCES	Contact/Report To: Maureen Doherty
Street Address: 53 Gibson Road, Goshen, NY 10924	Phone #: 845-781-4887
	E-Mail: Maureen.Doherty@ouboces.org
	Cc E-Mail: Halina.redner@ouboces.org
Customer Project #:	Invoice to: Halina Redner
Project Name: Pine Bush CSD - Circleville MS	Invoice E-mail: halina.redner@ouboces.org
Site Collection Info/Facility ID (as applicable):	Purchase Order # (if applicable): A24-00300
	Quote #:
Time Zone Collected: [ ] AK [X] PT [ ] MT [ ] CT [X] ET	County / State origin of sample(s): Orange County / New York
Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other	Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No
	Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other
	Date Results Requested:
	DW PWSID # or WW Permit # as applicable:
	Field Filtered (if applicable): [ ] Yes [ ] No
	Analysis:

Specify Container Size **: 3

Identify Container Preservative Type***: 2

Analysis Requested: Lead

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: / AcctNum / Client ID: / Table #: / Profile / Template: / Prelog / Bottle Ord. ID:

Sample Comment

Preservation non-conformance identified for sample.

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

	Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Lead
11	A75 girls locker Rm CU/BF	DW	G			6/11/24	3:45	1			X
12	A75 girls locker Rm CU/DF left	DW	G				3:46	1			X
13	A85 girls locker Rm CU/DF Right	DW	G				3:47	1			X
14	A85 boys locker Rm CU/BF	DW	G				3:43	1			X
15	A85 boys locker Rm CU/DF	DW	G				3:43	1			X
16	52A Home EC KS #1 L to R	DW	G				3:53	1			X
17	52A Home EC KS #2 L to R	DW	G				3:53	1			X
18	52A Home EC KS #3 L to R	DW	G				3:53	1			X
19	52A Home EC KS #4 L to R	DW	G				3:53	1			X
20	52A Home EC KS#5 L to R	DW	G				3:53	1			X

Additional Instructions from Pace® :

Collected By: Printed Name: Mikayla Higgins

Signature: Mikayla Higgins

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp. (°C):	Ice
				2.0	[X] On Ice

	Date/Time:	Received by/Company: (Signature)	Date/Time:	Tracking Number:
Relinquished by/Company: (Signature) Mikayla Higgins	6/13/24, 12:58		6/13/24	
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Delivered by: [ ] In-Person [ ] Courier [ ] FedEX [ ] UPS [ ] Other
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Page: 2 of 4

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

24F 1961-3

Scan QR Code for instructions

Company Name: Orange-Ulster BOCES	Contact/Report To: Maureen Doherty
Street Address: 53 Gibson Road, Goshen, NY 10924	Phone #: 845-781-4887
	E-Mail: Maureen.Doherty@ouboces.org
	Cc E-Mail: Halina.redner@ouboces.org
Customer Project #:	Invoice to: Halina Redner
Project Name: Pine Bush CSD - Circleville MS	Invoice E-mail: halina.redner@ouboces.org
Site Collection Info/Facility ID (as applicable):	Purchase Order # (if applicable): A24-00300
	Quote #:
Time Zone Collected: [ ] AK [X] PT [ ] MT [ ] CT [X] ET	County / State origin of sample(s): Orange County / New York
Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other	Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No
	Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other Date Results Requested:
	DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): [ ] Yes [ ] No Analysis:

Specify Container Size **: 3

Identify Container Preservative Type***: 2

Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: / AcctNum / Client ID: / Table #: / Profile / Template: / Prelog / Bottle Ord. ID:

Preservation non-conformance identified for sample.

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

	Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Lead	Sample Comment
21	O/S B219 CU/BF	DW	G			6/11/24	4:08	1			X	
22	O/S B219 CU/DF	DW	G				4:08	1			X	
23	O/S B205 CU/BF	DW	G				4:06	1			X	
24	O/S B205 CU/DF	DW	G				4:06	1			X	
25	O/S B144 CU/BF	DW	G				3:58	1			X	
26	O/S B144 CU/DF	DW	G				3:58	1			X	
27	O/S A36 BF	DW	G				3:48	1			X	
28	O/S A61 BF	DW	G				3:55	1			X	
29	Faculty / B131 KS	DW	G				3:57	1			X	
30	B 141 Kitchen Sink	DW	G				4:01	1			X	

Additional Instructions from Pace®:

Collected By: Printed Name: MiKayla Higgins

Signature: MiKayla Higgin

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp (°C):	[ ] On Ice
				2.0	ND

Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Tracking Number:
MiKayla Higgin	6/13/24, 12:58		6/13/24 1250	
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Delivered by: [ ] In- Person [ ] Courier
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	[ ] FedEX [ ] UPS [ ] Other
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Page: 3 of 4

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

24F1861-4

Scan QR Code for instructions

Company Name: Orange-Ulster BOCES	Contact/Report To: Maureen Doherty
Street Address: 53 Gibson Road, Goshen, NY 10924	Phone #: 845-781-4887
	E-Mail: Maureen.Doherty@ouboces.org
	Cc E-Mail: Halina.redner@ouboces.org
Customer Project #:	Invoice to: Halina Redner
Project Name: Pine Bush CSD - Circleville MS	Invoice E-mail: halina.redner@ouboces.org
Site Collection Info/Facility ID (as applicable):	Purchase Order # (if applicable): A24-00300
	Quote #:
Time Zone Collected: [ ] AK [X] PT [ ] MT [ ] CT [X] ET	County / State origin of sample(s): Orange County / New York
Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other	Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No
	Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other
	Date Results Requested:
	DW PWSID # or WW Permit # as applicable:
	Field Filtered (if applicable): [ ] Yes [ ] No
	Analysis:

Specify Container Size **: 3

Identify Container Preservative Type***: 2

Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: / AcctNum / Client ID: / Table #: / Profile / Template: / Prelog / Bottle Ord. ID:

Preservation non-conformance identified for sample.

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

	Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Lead	Sample Comment
31	Nurse's Sink	DW	G			6/11/24	4:03	1			X	
32	Cafe Right CU/BF					6/12/24	6:34					
33	O/S B 219 BF					6/12/24	6:36					

Additional Instructions from Pace® :

Collected By: Printed Name: Mikayla Higgins Signature: Mikayla Higgins

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp (°C):	[ ] On Ice
				2.0	ND

	Date/Time:	Received by/Company: (Signature)	Date/Time:
Relinquished by/Company: (Signature) Mikayla Higgins	6/13/24; 12:58		6/13/24 12:58
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:

Tracking Number:

Delivered by: [ ] In- Person [ ] Courier [ ] FedEX [ ] UPS [ ] Other

Page: 4 of 4

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Sample Condition Upon Receipt Form (SCUR)

Project # 24F18661

Client: Orange - Ulster

Date and Initials of person:
Examining contents:
Label:
Deliver to location:
pH:

Thermometer Used: IRG4 Date: 6/13 Time: 1258 Initials:

State of Origin: NY

Cooler #1 Temp.°C 24.0 **(Visual)** 0.2 @ 0.0°C, -0.5 @20.0°C **(Correction Factor)** 24.2 **(Actual)** ☑ Samples on ice, cooling process has begun

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☑ Client ☐ Commercial ☐ Pace ☐ Other

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground ☐ Other

Tracking #

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No **Seals intact:** ☐ Yes ☐ No **Ice:** (Wet) Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

		Comments:
Chain of Custody Present	☑Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☑Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☑Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☑Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☑Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐Yes ☐ No ☐ N/A	
Sufficient Volume	☑Yes ☐ No ☐ N/A	
Correct Containers Used	☑Yes ☐ No ☐ N/A	
Containers Intact	☑Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☑Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐Yes ☐ No ☐ N/A	Preservation Information: Preservative: Lot #/Trace #: Date: Time: Initials:
All Containers needing preservation are found to be in compliance with EPA recommendation: Exceptions: Vials, Microbiology, O&G, Metals	☐Yes ☐ No ☐ N/A	
Headspace in VOA Vials? (>6mm):	☐Yes ☐ No ☐N/A	
Trip Blank Present:	☐Yes ☐ No ☐N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: Date/Time:

Comments/Resolution: