315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890


July 2, 2024

Maureen Doherty
NB-Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Project Location: Pine Bush High School
Project Number: Pine Bush CSD-Pine Bush High School
Laboratory Work Order Number: 24F1860

Enclosed are results of analyses for samples received by the laboratory on June 13, 2024. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Project Manager

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924
ATTN: Maureen Doherty

REPORT DATE: 7/2/2024

PURCHASE ORDER NUMBER: A24-00300

PROJECT NUMBER: Pine Bush CSD-Pine Bush High School

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24F1860

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: Pine Bush High School

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
Pool CU/BF	24F1860-01	Drinking Water		EPA 200.8 Rev 5.4	
Pool CU/DF	24F1860-02	Drinking Water		EPA 200.8 Rev 5.4	
O/S Maint. 008 CU/BF	24F1860-03	Drinking Water		EPA 200.8 Rev 5.4	
O/S Maint. 008 CU/DF	24F1860-04	Drinking Water		EPA 200.8 Rev 5.4	
Breakroom Next to 007 KS	24F1860-05	Drinking Water		EPA 200.8 Rev 5.4	
O/S 022 CU/BF	24F1860-06	Drinking Water		EPA 200.8 Rev 5.4	
O/S 022 CU/DF	24F1860-07	Drinking Water		EPA 200.8 Rev 5.4	
Weight Room CU/BF	24F1860-08	Drinking Water		EPA 200.8 Rev 5.4	
Weight Room CU/DF Left	24F1860-09	Drinking Water		EPA 200.8 Rev 5.4	
Weight Room CU/DF Right	24F1860-10	Drinking Water		EPA 200.8 Rev 5.4	
O/S 111 CU/BF	24F1860-11	Drinking Water		EPA 200.8 Rev 5.4	
O/S 111 CU/DF	24F1860-12	Drinking Water		EPA 200.8 Rev 5.4	
111 Womens Locker CU/BF	24F1860-13	Drinking Water		EPA 200.8 Rev 5.4	
111 Womens Locker CU/DF Left	24F1860-14	Drinking Water		EPA 200.8 Rev 5.4	
111 Womens Locker CU/DF Right	24F1860-15	Drinking Water		EPA 200.8 Rev 5.4	
O/S 110 CU/BF	24F1860-16	Drinking Water		EPA 200.8 Rev 5.4	
O/S 110 CU/DF	24F1860-17	Drinking Water		EPA 200.8 Rev 5.4	
110 Mens Locker CU/DF Left	24F1860-18	Drinking Water		EPA 200.8 Rev 5.4	
110 Mens Locker CU/DF Right	24F1860-19	Drinking Water		EPA 200.8 Rev 5.4	
110 Mens Locker CU/BF	24F1860-20	Drinking Water		EPA 200.8 Rev 5.4	
DF by 100 Library	24F1860-21	Drinking Water		EPA 200.8 Rev 5.4	
O/S 113 CU/BF	24F1860-22	Drinking Water		EPA 200.8 Rev 5.4	
O/S 113 CU/DF	24F1860-23	Drinking Water		EPA 200.8 Rev 5.4	
116 CS	24F1860-24	Drinking Water		EPA 200.8 Rev 5.4 (1994)	
119 Faculty KS	24F1860-25	Drinking Water		EPA 200.8 Rev 5.4	
DF O/S 132 Prep	24F1860-26	Drinking Water		EPA 200.8 Rev 5.4	
Kitchen Vegetable KS	24F1860-27	Drinking Water		EPA 200.8 Rev 5.4	
Kitchen KF 1	24F1860-28	Drinking Water		EPA 200.8 Rev 5.4	
144 Faculty KS	24F1860-29	Drinking Water		EPA 200.8 Rev 5.4	
DF O/S 164 Prep	24F1860-30	Drinking Water		EPA 200.8 Rev 5.4	
142 KS #1 L to R	24F1860-31	Drinking Water		EPA 200.8 Rev 5.4	
142 KS #2 L to R	24F1860-32	Drinking Water		EPA 200.8 Rev 5.4	
142 KS #4 L to R	24F1860-33	Drinking Water		EPA 200.8 Rev 5.4	
142 KS #5 L to R	24F1860-34	Drinking Water		EPA 200.8 Rev 5.4	
167 CS	24F1860-35	Drinking Water		EPA 200.8 Rev 5.4	
O/S 181 CU/BF	24F1860-36	Drinking Water		EPA 200.8 Rev 5.4	
O/S 181 CU/DF	24F1860-37	Drinking Water		EPA 200.8 Rev 5.4	
DF Across 183	24F1860-38	Drinking Water		EPA 200.8 Rev 5.4	
184 Cafe CU/BF	24F1860-39	Drinking Water		EPA 200.8 Rev 5.4	

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924
ATTN: Maureen Doherty

REPORT DATE: 7/2/2024

PURCHASE ORDER NUMBER: A24-00300

PROJECT NUMBER: Pine Bush CSD-Pine Bush High School

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24F1860

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: Pine Bush High School


FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
184 Cafe CU/DF	24F1860-40	Drinking Water		EPA 200.8 Rev 5.4	
O/S 209 CU/BF	24F1860-41	Drinking Water		EPA 200.8 Rev 5.4	
O/S 209 CU/DF	24F1860-42	Drinking Water		EPA 200.8 Rev 5.4	
209 Faculty KS	24F1860-43	Drinking Water		EPA 200.8 Rev 5.4	
Nurse's Ice	24F1860-44	Drinking Water		EPA 200.8 Rev 5.4	
Kitchen Ice	24F1860-45	Drinking Water		EPA 200.8 Rev 5.4	
Athletic Director Ice	24F1860-46	Drinking Water		EPA 200.8 Rev 5.4	

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.
I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Felicia Morgan-Nichols
Project Manager

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: Pool CU/BF | Sampled: 6/12/2024 03:36

Sample ID: 24F1860-01

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 17:28	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: Pool CU/DF | Sampled: 6/12/2024 03:36

Sample ID: 24F1860-02

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 17:45	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S Maint. 008 CU/BF | Sampled: 6/12/2024 03:32

Sample ID: 24F1860-03

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 17:48	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S Maint. 008 CU/DF | Sampled: 6/12/2024 03:32

Sample ID: 24F1860-04

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 17:50	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: Breakroom Next to 007 KS | Sampled: 6/12/2024 03:33

Sample ID: 24F1860-05

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	6.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 17:53	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 022 CU/BF | Sampled: 6/12/2024 03:34

Sample ID: 24F1860-06

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 17:56	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 022 CU/DF | Sampled: 6/12/2024 03:34

Sample ID: 24F1860-07

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 17:59	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: Weight Room CU/BF | Sampled: 6/12/2024 03:45

Sample ID: 24F1860-08

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:01	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: Weight Room CU/DF Left | Sampled: 6/12/2024 03:45

Sample ID: 24F1860-09

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:04	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: Weight Room CU/DF Right | Sampled: 6/12/2024 03:45

Sample ID: 24F1860-10

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:12	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 111 CU/BF | Sampled: 6/12/2024 03:39

Sample ID: 24F1860-11

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:15	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 111 CU/DF | Sampled: 6/12/2024 03:39

Sample ID: 24F1860-12

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:21	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 111 Womens Locker CU/BF | Sampled: 6/12/2024 03:39

Sample ID: 24F1860-13

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:23	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 111 Womens Locker CU/DF Left | Sampled: 6/12/2024 03:39

Sample ID: 24F1860-14

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:26	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 111 Womens Locker CU/DF Right | Sampled: 6/12/2024 03:39

Sample ID: 24F1860-15

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:29	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 110 CU/BF | Sampled: 6/12/2024 03:41

Sample ID: 24F1860-16

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:32	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 110 CU/DF | Sampled: 6/12/2024 03:41

Sample ID: 24F1860-17

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:34	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 110 Mens Locker CU/DF Left | Sampled: 6/12/2024 03:42

Sample ID: 24F1860-18

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:37	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 110 Mens Locker CU/DF Right | Sampled: 6/12/2024 03:42

Sample ID: 24F1860-19

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:45	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 110 Mens Locker CU/BF | Sampled: 6/12/2024 03:42

Sample ID: 24F1860-20

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:48	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: DF by 100 Library | Sampled: 6/12/2024 03:59

Sample ID: 24F1860-21

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 18:51	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 113 CU/BF | Sampled: 6/12/2024 04:18

Sample ID: 24F1860-22

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:02	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 113 CU/DF | Sampled: 6/12/2024 04:18

Sample ID: 24F1860-23

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:05	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 116 CS | Sampled: 6/12/2024 04:18

Sample ID: 24F1860-24

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	1.9		1.5	µg/L	1		EPA 200.8 Rev 5.4 (1994)	6/25/24	7/1/24 13:35	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 119 Faculty KS | Sampled: 6/12/2024 04:20

Sample ID: 24F1860-25

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:07	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: DF O/S 132 Prep | Sampled: 6/12/2024 04:16

Sample ID: 24F1860-26

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:10	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: Kitchen Vegetable KS | Sampled: 6/12/2024 04:06

Sample ID: 24F1860-27

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	1.8	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:18	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: Kitchen KF 1 | Sampled: 6/12/2024 04:06

Sample ID: 24F1860-28

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:21	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 144 Faculty KS | Sampled: 6/12/2024 03:55

Sample ID: 24F1860-29

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	4.1	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:24	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: DF O/S 164 Prep | Sampled: 6/12/2024 04:14

Sample ID: 24F1860-30

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:27	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 142 KS #1 L to R | Sampled: 6/12/2024 03:52

Sample ID: 24F1860-31

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:29	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 142 KS #2 L to R | Sampled: 6/12/2024 03:52

Sample ID: 24F1860-32

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	1.1	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:32	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 142 KS #4 L to R | Sampled: 6/12/2024 03:52

Sample ID: 24F1860-33

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:38	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 142 KS #5 L to R | Sampled: 6/12/2024 03:52

Sample ID: 24F1860-34

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	1.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:40	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 167 CS | Sampled: 6/12/2024 04:13

Sample ID: 24F1860-35

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:43	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 181 CU/BF | Sampled: 6/12/2024 04:10

Sample ID: 24F1860-36

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:51	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 181 CU/DF | Sampled: 6/12/2024 04:10

Sample ID: 24F1860-37

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:54	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: DF Across 183 | Sampled: 6/12/2024 04:03

Sample ID: 24F1860-38

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 19:57	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 184 Cafe CU/BF | Sampled: 6/12/2024 04:04

Sample ID: 24F1860-39

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 20:00	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 184 Cafe CU/DF | Sampled: 6/12/2024 04:04

Sample ID: 24F1860-40

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 20:02	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 209 CU/BF | Sampled: 6/12/2024 04:23

Sample ID: 24F1860-41

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 20:05	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: O/S 209 CU/DF | Sampled: 6/12/2024 04:23

Sample ID: 24F1860-42

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 20:08	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: 209 Faculty KS | Sampled: 6/12/2024 04:23

Sample ID: 24F1860-43

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	2.1	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 20:25	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: Nurse's Ice | Sampled: 6/12/2024 03:56

Sample ID: 24F1860-44

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 20:27	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: Kitchen Ice | Sampled: 6/12/2024 04:06

Sample ID: 24F1860-45

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	1.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 20:30	JC

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Pine Bush High School | Sample Description: | Work Order: 24F1860

Date Received: 6/13/2024

Field Sample #: Athletic Director Ice | Sampled: 6/12/2024 03:43

Sample ID: 24F1860-46

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	6/20/24	6/24/24 20:33	JC

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level

Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.

No results have been blank subtracted unless specified in the case narrative section.

315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 Rev 5.4 in Drinking Water	
Lead	NB-CT,NB-NJ,NB-NY
EPA 200.8 Rev 5.4 (1994) in Water	
Lead	NB-CT,NB-NJ,NB-NY

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2024
NB-NY	New York State Department of Health	10142 NELAP	03/31/2025

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

24F1860-1

Scan QR Code for instructions

Company Name: Orange-Ulster BOCES	Contact/Report To: Maureen Doherty
Street Address: 53 Gibson Road, Goshen, NY 10924	Phone #: 845-781-4887
	E-Mail: Maureen.Doherty@ouboces.org
	Cc E-Mail: Halina.redner@ouboces.org
Customer Project #:	Invoice to: Halina Redner
Project Name: Pine Bush CSD - ~~Circleville MS~~ Pine Bush HS	Invoice E-mail: halina.redner@ouboces.org
Site Collection Info/Facility ID (as applicable):	Purchase Order # (if applicable): A24-00300
	Quote #:
Time Zone Collected: [ ] AK [X] PT [ ] MT [ ] CT [X] ET	County / State origin of sample(s): Orange County / New York
Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other	Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No
Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other	DW PWSID # or WW Permit # as applicable:
Date Results Requested:	Field Filtered (if applicable): [ ] Yes [ ] No
	Analysis:

Specify Container Size **

Identify Container Preservative Type***

Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: / AcctNum / Client ID: / Table #: / Profile / Template: / Prelog / Bottle Ord. ID:

Preservation non-conformance identified for sample.

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

	Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Lead	Sample Comment
1	Pool CU/BF	DW	G			6/12/24	3:36	1			X	
2	Pool CU/DF	DW	G				3:36	1			X	
3	O/S maint. 008 CU/BF	DW	G				3:32	1			X	
4	O/S maint. 008 CU/DF	DW	G				3:32	1			X	
5	Breakroom next to 007 KS	DW	G				3:33	1			X	
6	O/S 022 CU/BF	DW	G				3:34	1			X	
7	O/S 022 CU/DF	DW	G				3:34	1			X	
8	weight room CU/BF	DW	G				3:45	1			X	
9	weight room CU/DF Left	DW	G				3:45	1			X	
10	weight room CU/DF Right	DW	G				3:45	1			X	

24F1860

Additional Instructions from Pace® :

Collected By: Printed Name: MiKayla Higgins Signature: MiKayla Higgins

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp. (°C):	[ ] On Ice
				2.0	ND

Relinquished by/Company: (Signature) MiKayla Higgins	Date/Time: 6/13/24; 12:58	Received by/Company: (Signature)	Date/Time: 6/13/24 1258	Tracking Number:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Delivered by: [ ] In-Person [ ] Courier [ ] FedEx [ ] UPS [ ] Other
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Page: 1 of 5

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

24F1860-2

Scan QR Code for instructions

Company Name: Orange-Ulster BOCES
Street Address: 53 Gibson Road, Goshen, NY 10924
Customer Project #:
Project Name: Pine Bush HS / Pine Bush CSD - ~~Circleville MS~~
Site Collection Info/Facility ID (as applicable):

Contact/Report To: Maureen Doherty
Phone #: 845-781-4887
E-Mail: Maureen.Doherty@ouboces.org
Cc E-Mail: Halina.redner@ouboces.org
Invoice to: Halina Redner
Invoice E-mail: halina.redner@ouboces.org
Purchase Order # (if applicable): A24-00300
Quote #:

Time Zone Collected: [ ] AK [X] PT [ ] MT [ ] CT [X] ET
County / State origin of sample(s): Orange County / New York

Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other
Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No
Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other
Date Results Requested:
DW PWSID # or WW Permit # as applicable:
Field Filtered (if applicable): [ ] Yes [ ] No
Analysis:

Specify Container Size **: 3
Identify Container Preservative Type***: 2
Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: / AcctNum / Client ID: / Table #: / Profile / Template: / Prelog / Bottle Ord. ID:

Preservation non-conformance identified for sample.

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

	Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Lead	Sample Comment
11	0/S 111 CU/BF	DW	G		~~3:39~~	6/12/24	3:39	1			X	
12	0/S 111 CU/DF	DW	G		~~3:39~~		3:39	1			X	
13	111 womens locker CU/BF	DW	G				3:39	1			X	
14	111 womens locker CU/DF left	DW	G				3:39	1			X	
15	111 womens locker CU/DF Right	DW	G				3:39	1			X	
16	0/S 110 CU/BF	DW	G				3:41	1			X	
17	0/S 110 CU/DF	DW	G				3:41	1			X	
18	110 mens locker CU/DF left	DW	G				3:42	1			X	
19	110 mens locker CU/DF Right	DW	G				3:42	1			X	
20	110 mens locker CU/BF	DW	G				3:42	1			X	

Additional Instructions from Pace®:

Collected By:
Printed Name: MiKayla Higgins
Signature: MiKayla Higgins

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp. (°C):	[ ] On Ice
				2.0	NO

	Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
1	MiKayla Higgins	6/13/24; 12:58		6/13/24 1258
2				
3				
4				

Tracking Number:
Delivered by: [ ] In- Person [ ] Courier [ ] FedEx [ ] UPS [ ] Other

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

24F1860-3

Scan QR Code for instructions

Company Name: Orange-Ulster BOCES
Street Address: 53 Gibson Road, Goshen, NY 10924
Customer Project #:
Project Name: Pine Bush CSD - ~~Circleville MS~~ Pine Bush HS
Site Collection Info/Facility ID (as applicable):

Contact/Report To: Maureen Doherty
Phone #: 845-781-4887
E-Mail: Maureen.Doherty@ouboces.org
Cc E-Mail: Halina.redner@ouboces.org
Invoice to: Halina Redner
Invoice E-mail: halina.redner@ouboces.org
Purchase Order # (if applicable): A24-00300
Quote #:

Time Zone Collected: [ ] AK [X] PT [ ] MT [ ] CT [X] ET
County / State origin of sample(s): Orange County / New York

Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other
Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No
Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other
Date Results Requested:
DW PWSID # or WW Permit # as applicable:
Field Filtered (if applicable): [ ] Yes [ ] No
Analysis:

Specify Container Size **: 3
Identify Container Preservative Type***: 2
Analysis Requested: Lead

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: / AcctNum / Client ID: / Table #: / Profile / Template: / Prelog / Bottle Ord. ID:

Preservation non-conformance identified for sample.

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

	Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Sample Comment
21	DF by 100 Library	DW	G			6/12/24	3:59	1			
22	O/S 113 CH/BF	DW	G				4:18	1			
23	O/S 113 CH/DF	DW	G				4:18	1			
24	116 CS	DW	G				4:18	1			
25	119 Faculty KS	DW	G				4:20	1			
26	DF O/S 132 Prep	DW	G				4:16	1			
27	Kitchen vegetable KS	DW	G				4:06	1			
28	Kitchen KF 1	DW	G				4:06	1			
29	144 Faculty KS	DW	G				3:55	1			
30	DF O/S 164 Prep	DW	G				4:14	1			

Additional Instructions from Pace® :

Collected By: Printed Name: Mikayla Higgins Signature: Mikayla Higgins

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp. (°C):	[ ] On Ice
				2.0	Yes

Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
Mikayla Higgins	6/13/24; 12:58		6/13/24 1258

Tracking Number:

Delivered by: [ ] In- Person [ ] Courier [ ] FedEx [ ] UPS [ ] Other

Page: 3 of 5

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here: 24F1860-4

Scan QR Code for instructions

Company Name: Orange-Ulster BOCES	Contact/Report To: Maureen Doherty
Street Address: 53 Gibson Road, Goshen, NY 10924	Phone #: 845-781-4887
	E-Mail: Maureen.Doherty@ouboces.org
	Cc E-Mail: Halina.redner@ouboces.org
Customer Project #:	Invoice to: Halina Redner
Project Name: Pine Bush CSD - ~~Circleville MS~~ Pine Bush HS	Invoice E-mail: halina.redner@ouboces.org
Site Collection Info/Facility ID (as applicable):	Purchase Order # (if applicable): A24-00300
	Quote #:
Time Zone Collected: [ ] AK [X] PT [ ] MT [ ] CT [X] ET	County / State origin of sample(s): Orange County / New York
Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other	Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No
Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other	DW PWSID # or WW Permit # as applicable:
Date Results Requested:	Field Filtered (if applicable): [ ] Yes [ ] No
	Analysis:

Specify Container Size **: 3

Identify Container Preservative Type***: 2

Analysis Requested: Lead

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: / AcctNum / Client ID: / Table #: / Profile / Template: / Prelog / Bottle Ord. ID:

Preservation non-conformance identified for sample.

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

	Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Sample Comment
31	142 KS #1 L to R	DW	G			6/12/24	3:52	1			X
32	142 KS #2 L to R	DW	G				3:52	1			X
33	142 KS #4 L to R	DW	G				3:52	1			X
34	142 KS #5 L to R	DW	G				3:52	1			X
35	167 CS	DW	G				4:13	1			X
36	O/S 181 CU/BF	DW	G				4:10	1			X
37	O/S 181 CU/DF	DW	G				4:10	1			X
38	DF across 183	DW	G				4:03	1			X
39	184 Cafe CU/BF	DW	G				4:04	1			X
40	184 Cafe CU/DF	DW	G				4:04	1			X

Additional Instructions from Pace®:

Collected By: Printed Name: MiKayla Higgins

Signature: MiKayla Higgins

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp (°C):	[ ] On Ice
				2.0	NJ

Relinquished by/Company: (Signature) MiKayla Higgins	Date/Time: 6/13/24, 12:58	Received by/Company: (Signature)	Date/Time: 6/13/24 1258	Tracking Number:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Delivered by: [ ] In-Person [ ] Courier [ ] FedEx [ ] UPS [ ] Other
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Page: 4 of 5

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

24F1860-5

Scan QR Code for instructions

Company Name: Orange-Ulster BOCES
Street Address: 53 Gibson Road, Goshen, NY 10924
Customer Project #:
Project Name: Pine Bush CSD - ~~Circleville MS~~ Pine Bush HS
Site Collection Info/Facility ID (as applicable):

Contact/Report To: Maureen Doherty
Phone #: 845-781-4887
E-Mail: Maureen.Doherty@ouboces.org
Cc E-Mail: Halina.redner@ouboces.org
Invoice to: Halina Redner
Invoice E-mail: halina.redner@ouboces.org
Purchase Order # (if applicable): A24-00300
Quote #:

Time Zone Collected: [ ] AK [X] PT [ ] MT [ ] CT [X] ET
County / State origin of sample(s): Orange County / New York

Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other
Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No
Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other
Date Results Requested:
DW PWSID # or WW Permit # as applicable:
Field Filtered (if applicable): [ ] Yes [ ] No
Analysis:

Specify Container Size **: 3
Identify Container Preservative Type***: 2
Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: / AcctNum / Client ID: / Table #: / Profile / Template: / Prelog / Bottle Ord. ID:

Preservation non-conformance identified for sample.

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW),Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

	Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Lead	Sample Comment
41	O/S 209 CH/3F	DW	G			6/12/24	4:23	1			X	
42	O/S 209 CH/DF	DW	G				4:23	1			X	
43	209 Faculty KS	DW	G				4:23	1			X	
44	Nurse's Ice	DW	G				3:56	1			X	
45	Kitchen Ice	DW	G				4:06	1			X	
46	Athletic Director Ice	DW	G			↓	3:43	1			X	

Additional Instructions from Pace®:

Collected By: Printed Name: Mikayla Higgins
Signature: Mikayla Higgins

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp. (°C):	[ ] On Ice
				2.0	NO

Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Tracking Number:
Mikayla Higgins	6/13/24; 12:58		6/13/24 0250	
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Delivered by: [ ] In-Person [ ] Courier [ ] FedEx [ ] UPS [ ] Other
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Page: 5 of 5

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Sample Condition Upon Receipt Form (SCUR)

Project # 24F1860
Client: OUBOCES

Date and Initials of person:
Examining contents:
Label:
Deliver to location:
pH:

Thermometer Used: IRG4 Date: 6/13 Time: 1258 Initials:

State of Origin: NY

Cooler #1 Temp.°C 24.0 **(Visual)** 0.2 @ 0.0°C, -0.5 @20.0°C **(Correction Factor)** _____ **(Actual)** ☒ ~~Samples on ice, cooling process has begun~~

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other_____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground ☐ Other_____

Tracking # _____

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No **Seals intact:** ☐ Yes ☐ No **Ice:** ~~Wet~~ Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other_____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

		Comments:
Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information: Preservative:_____ Lot #/Trace #:_____ Date:_____ Time:_____ Initials:_____
All Containers needing preservation are found to be in compliance with EPA recommendation: Exceptions: Vials, Microbiology, O&G, Metals	☐ Yes ☐ No ☐ N/A	
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution
Person Contacted: Date/Time:
Comments/Resolution: